

**OFFICE OF THE EXECUTIVE ENGINEER (PLG)W-III
DELHI JAL BOARD, VARUNALAYA PH-I,
JHANDEWALAN, KAROL BAGH NEW DELHI-5**

No.DJB/EE(PL)W-III/2015 / 2778

Date: 02/02/16

CIRCULAR

(Amendment No. 1 to Circular Dt. 24.08.2015)

Sub: Estimation of average daily water demand for approval of Bulk Water Supply Schemes in Planning Cell- criteria for categorisation of EWS/LIG Housing.

In continuation to circular no. DJB/EE(Plg)W-I/2015/ dt 24.08.2015, it has been decided that a dwelling unit with a carpet area upto 40 sqm will be considered as EWS/LIG category, wherein these have not been specified by building/development plans sanctioning public authorities like DDA, MCD or any other Government approved public authority for the purpose. The water demand for these units is to be considered @ 135 lpcd for the purpose of working out IF charge.

This is being issued as per approval of the competent authority i.e. CE(Plg)Water.



-S/-
EE(Plg)W-III

1. Secretary to CEO
2. Member(A)/Member(F)/Member(Dr)/Member(W)/CVO/Secretary, DJB
3. All CE(C)Maintenance zones.
4. Director (A&P)/Director (F&A)/DOR
5. All SEs (Civil) Maintenance Zones/Jt. Director(R)
6. Consultant (PR)/All EEs (Civil)Maintenance Zone/All ZROs
7. EE(EDP) with request to upload on DJB websites (suggested path : Home page>Circular>Planning Water.
8. Office Copy

Jh. Jantar

Pras - I

15-2-16

-S/-
EE(Plg)W-III