

NO.F6/DFS/MS/2011/EH/1950

Dated: 12/08/11

FIRE SAFETY CERTIFICATE

Certified that the M/s Pind Balluchi located at Plot No 16, 17, Sector-10, Commercial Complex, Dwarka, New Delhi is running at first floor, comprised of ground plus three upper floors was granted NOC by this department vide letter No. F:6/DFS/MS/EH/2010/1387 dated 12.05-2010 have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi fire service on 29.07.2011 in the presence of Mr. Surya Prakash, Manager of the restaurant and that the building/premises is fit for occupancy class **Assembly building (Restaurant)** with effect from ~~12/08/11~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions given below.

Issued on ~~12/08/11~~ at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, MCD, Najafgarh Zone, New Delhi
2. The Owner / Occupier, M/s Pind Balluchi, Plot No 16, 17, Sector-10, Commercial Complex, Dwarka, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

May kindly peruse the letter dated 04.07.2011 received from the Authorized Signature, Pind Balluchi, (Unit of An Elegant Hospitality) Plot No. 16,17 Commercial Complex, Sector 10, Dwarka New Delhi-110075. regarding **renewal** of NOC from fire safety point of view in r/o Pind Balluchi Restaurant at Plot No.16, 17, 1st floor, Commercial Complex, Sector-10, Dwarka, New Delhi-110075.

In this connection it is stated that the above said premises has been inspected by DO Virender Singh along with D.O Dharam Pal Bharadwaj on 29.07.2011 with the view to see the compliance of fire safety recommendation as per part IV national building code 2005.

During the course of inspection it has been observed that the restaurant is running at the first floor, comprised of ground plus three upper floors. Other observation are as under:-

S.No.	Fire Safety Provisions	Provided / Not Required	Remarks
1.	Access to building	Provided	Main Road.
2.	Number, Width Type Arrangement of exits	Provided	Staircases : 1 Nos. (width of stairs-121cm.) with two exit
3.	Protection of Exits	Not required	-----
4.	Compartmentation	Not required	-----
5.	Smoke Management System	Not required	Natural Ventilation
6.	Fire Extinguishers	Provided	Five ABC type having capacity 5 kg. ISI marked are found provided.
7.	First-Aid Hose Reels	Provided	One hose reel is found provided.
8.	Automatic fire detection and alarming system	Not required	-----
9.	MOEFA	Not required	-----
10.	Public Address System	Not required	-----
11.	Automatic Sprinkler System	Provided	Entire floor.
12.	Internal Hydrants and Yard Hydrants	Provided	Down comer is found provided.
13.	Pumping Arrangements	Provided	The fire pump having 450 LPM and one jockey Pump having 180 LPM at 40 meters head in auto operation is found installed at terrace.
14.	Water Storage for fire fighting	Provided	An over head water storage tank having capacity 5000 ltrs. is found provided.
15.	Exit Signage	Provided	Found provided-
16.	Provision of Lifts	Not required	-----
17.	Standby power supply	Provided	
18.	Refuge Area	Not required	-----
19.	Fire Control Room	Not required	-----
20.	Special Fire Protection Systems for Protection of special Risks	Not required	-----

The above said fire safety equipments are found functional at the time of inspection.

In view of the above, the restaurant building may be considered for **renewal** of (NOC) fire safety certificate from the fire safety point of view. This department had already issued NOC for the restaurant building vide letter no. F.6/MS/DFS/EH/2010/1387 dated 12.05.2010. The draft fire safety certificate on form H is placed on file for approval and signatures.

Submitted Please

1. Spoken on 5/8.

2. Revised DTR is placed opp /m

Asst
+
FT
Year
Dino
5/8

Dino
5/8

The Fire Safety Certificate is put up for signatures, please.

~~5/8~~

Dino
15/8

Red
10/8/11

MS