

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**

No: FG/DFS/MS/EH/2011/1958

Dated: 12/08/2011

FIRE SAFETY CERTIFICATE

Certified that the restaurant in the name & style of M/s. PVR BLUO ENTERTAINMENT at first floor block No. II of Ambience Mall building, Plot No.2, Vasant Kunj, Phase-II, New Delhi comprised of three basements, ground plus three upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service rules, 2010 and verified by the officer concerned of fire service on 29-07-2011 in the presence of Mr. Sunil Bhatnagar, Vice President (Liaison) and building is fit for occupancy class for restaurant with effect from...12/08/11... for a period of three years in accordance with rule 36 unless renewed under rule 37 of sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/08/11 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE
of
man

Copy to

1. The Dy. Health Officer,
Municipal Corporation of Delhi,
Health Department, South Zone,
Green Park, New Delhi - 110016
2. Sh. Gautam Dutta,
M/s. PVR Bluo Entertainment,
First Floor, Ambience Mall,
Vasant Kunj, New Delhi

Note* :- For general fire safety directives please see overleaf.

May kindly see the above mentioned letter received from The Dy. Health Officer, Municipal Corporation of Delhi, Health Department, South Zone, Green Park, New Delhi - 110016 regarding grant of NOC in respect of M/s. PVR Blu Entertainment, First Floor, Ambience Mall, Vasant Kunj, New Delhi

In this connection, it is to inform you that the inspection of the above mentioned restaurant has been carried out by ADO (Safdarjung) on 29-07-2011 to verify the existing fire safety arrangements. At the time of inspection, Sh. Sunil Bhatnagar, Vice President (Liaison) with the other staff was also present.

During the course of inspection, it has been observed that the restaurant is running at first floor (block No. II) of Ambience Mall building, Plot No.2, Vasant Kunj, Phase-II, New Delhi comprised of three basements, ground plus three upper floors. There is sitting arrangements in the central area of the restaurant and both side of the same 12 x 2 bowling lines been provided. There is also bar / bar store, cash counter, kitchen in rear portion. The fire protection system provided in the entire restaurant is duly connected with the mall building. The building is accessible to fire engines in case of emergency through a road of sufficient width. Further the following fire safety arrangements required under rule 33 are provided.

1. Access to Building : Provided (main road)
2. Number, Width, Type and arrangement of exits : Provided (Five Exit Gates having width of 2 mtr. Of two Exits and three exits are of 1.50 mtr. each).
3. Protection of Exits by means of fire check door(s) and or pressurization : Provided
4. Compartmentation : Provided
5. Smoke management system : Provided (Exhaust Fans)
6. Fire Extinguishers : Provided
7. First Aid Hose Reels : Provided (common to mall building)
8. Automatic Fire Detection and alarming system : Provided (common to mall building)
9. MOEFA : (Manually Operated Electric Fire Alarm) : Provided (common to mall building)
10. Public Address System : Provided (common to mall building)
11. Automatic sprinkler system : Provided in the entire restaurant
12. Internal Hydrant and yard Hydrant : Provided (common to mall building)
13. Pumping arrangements : Provided (common to mall building) (Main & Jockey pump) & Diesel Driven Fire Pump.
14. Captive water storage for fire fighting : Provided (OHWS Tank 30000 ltrs. and UGWS Tank 2,00,000 Ltrs.)
15. Exit Signage : Provided at each exit.

contd. :-

- 17. Stand by power supply : Provided (DG set common to mall building)
- 18. Refuge Area : Not Required.
- 19. Fire Control Room : Provided
- 20. Special Fire Protection system for protection of Special risks : 05
Nos. ABC type fire extinguishers having capacity of 5 kg: ISI marked provided near electric panel board.

The above mentioned fire arrangements were checked / operated randomly and found functional at the time of inspection.

In view of the above grant of NOC from fire safety point of view is recommended. Fire safety certificate is put up in the shape of DFA for your approval and signature if approved please.

DO (BCP)

[Signature]
5/8/11

DCFO (I)

[Signature]
9/8

CFO
[Signature]
1/7/8

[Signature]
10/8

[Signature]

[Signature]
29-7-11
ADP (CT)

F.F. letter is put-up for sign. pl

[Signature]

[Signature]
11/8

[Signature]
11/8/11

MS