

No F6(DFS) MSJ 2011/1923

Dated : 1-1-08/2011

FIRE SAFETY CERTIFICATE

Certified that the **ST. ANGEL'S SCHOOL** comprised of basement, ground and three upper floors thus more than 9 meters and located at **A-Block, Sector-15, Rohini, Delhi-110 085**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 28.07.2011 (date of inspection) in the presence of **Shri Ashutosh Bhardwaj** and that the building/premises is fit for occupancy under **Educational class** with effect from 1-1-08/2011 for a period of **3 (three)** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the condition under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on1-1-08/2011..... at New Delhi by

Shri Ashutosh Bhardwaj,
ST. ANGEL'S SCHOOL,
A-Block, Sector-15, Rohini,
Delhi-110 085.


Chief Fire Officer
Delhi Fire Service

o/c
msw

Copy to :

The Director,
Kashmiri Gate, Delhi.

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

May kindly see the letter No. Nil dated Nil received from Manager At. Angel's School, A-Block, Sector-15, Rohini, Delhi-110085, regarding the NOC from fire safety and fire prevention point of view. In this connection the premises was inspected by the undersigned in the presence of Shri Ashutosh Bhardwaj on 28/07/2011 as per the Delhi Fire Service Act, 2007 and Delhi Fire Service Rules,2010.

During the course of inspection it has been observed that the school is running in a basement, ground and three upper floors and having a total covered area of 6089 sq. meters and building is constructed on an area of 3600 square meters approximately situated on 30 meters wide road and is accessible through 5 meters wide gate. All the class rooms have less than 45 children and have single door of width 120 cms.

S.No	Fire Safety provision	Provided/Not Provided
1	Access to building	Fire Engine is accessible
2	Number, Width type and arrangement of exits	Two staircase in each block are provided in 1 st Block-158cm (concrete) each: 2 nd Block-120 cms of concrete & 150 cms of iron and 3 rd Block-120 cms of concrete & 150 cms of iron
3	Protection of Exits by means of fire check door (s) and or pressurization	Not required
4	Compartmentation	Not required
5	Smoke Managements System	Not required, However Natural and Mechanical ventilation with exhaust fans available
6	Fire Extinguishers	Provided
7	Fire Aid Hose Reels	Provided
8	Automatic Fire detection and alarming system	Not required
9	MOEF A	Not required
10	Public Address System	Provided
11	Automatic Sprinkler System	Provided in entire basement
12	Internal Hydrants and Yard Hydrants	Not required
13	Pumping Arrangements	Terrace pump of 900 lpm pump and a jockey pump of 180 lpm is provided.
14	Captive Water Storage for fire fighting	overhead tank of 15,000 liters & underground tank of 50,000 liters are provided
15	Exit Signage	Provided
16	Provision of lifts	Not required <i>as No lift</i>
17	Standby power Supply	Not required
18	Refuge Area	Not Required
19	Fire Control Room	Not required
20	Special Fire Protection Systems	Not required

572659

2700

Recommended

2000
218

~~Depto~~

8/13

~~CFO~~
9/18

~~F.T.~~
1/20

9/18

F.T. letter is put-up for sign-off

1/20

~~CFO~~
1/20

MS