

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No F6/DFS/MS/EH/2011/1987

Dated 12/08/2011

FIRE SAFETY CERTIFICATE

Certified that the Restaurant at Essex Farms, 4, Aurbindo Marg, New Delhi, being run at the ground floor of the bldg. which comprises ground floor only, was granted NOC by this deptt. vide letter No. F6 / DFS / MS / EH / 2005 / 1481 dated 13- 7 - 2005. The premises was re-inspected by the officer concerned of this department on 28 -7-2011 in the presence of Mr.Mathur & other tech. staff and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for Restaurant occupancy with effect from 12-8-2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 12-08-2011 at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to :-

1. M/S Essex Farms
4, Aurbindo Marg, New Delhi
2. Dy. Health Officer
Health Department South Zone
Green Park, New Delhi.

9/



Ref:- Letter No. DHO/HO/SZ/2011/D/688 dt. 22/6/11

with ref. above quoted letter, it is submitted that NOC was issued by this dept vide letter no. F6/m/s, EH/2005/1481 dated 13.7.05 on the bases of below stated fire protection arrangements.

1. Hose Reel — Provided.
2. Down Corner System — Not required
3. Automatic Sprinkler System — Not required.
4. Manual fire alarm System (map) — Provided.
5. Overhead tanks — Provided (2,500 litres)
6. Fire Pump — 225 LPM, 28mtr head
Provided.
7. Fire Extinguishers — Provided (CO₂, ABC Type)
8. Access to bldg. — Available (11-5mtr.)
9. Emergency lights — Provided - (battery back)
10. Exit Signs — Provided.
11. Emergency Supply — Provided (DG set)
12. Means of Escape — Provided (2 Exits) ^(1.55)_(1.05)
13. Smoke Venting — Provided (exhaust fan)
14. Concealed Type elec wiring
MCBs/ELCBs — Provided.

In view of the report on prepage
renewal of fire safety Certificate is recommended
and accordingly draft fire safety Certificate is
put up for approval/sign.

Submitted please.

~~DO (BCP)~~

~~10/8/11~~

~~10/8/11~~

~~10/8/11~~

width of the exit to be
mentioned in noting II

Safety

~~DO (ND)~~

The width of exit is shown in the
inspection report.

Re-submitted please.

~~DO (BCP)~~
~~10/8/11~~

~~10/8/11~~

~~CFP~~
10/8

Which class of occupancy?