

May kindly peruse the letter no. Nil dated 21.6.2011 received from the Principal, Bal Bhawan Public school, A-Block, Swasthya Vihar, Delhi-92 regarding issuance of NOC from fire safety point of view. In this connection it is submitted that the premises in question was inspected by the D.O (LN) Vijay Bahadur on 20.7.2011 and 30.7.2011 with a view check the fire safety arrangements as per NBC Part IV. Shri Kunal Gupta, the Principal with other staff was also present during inspection. During inspection it was observed that the school building is comprised of basement, ground and 1st floor. Details of fire safety arrangements and means of escape are as under:-

1. Access: Provided. The building is abutting on 30 mtrs. Wide road with 6 mtrs. Wide main gate.
2. Number, width, type of exits: There is one staircase of 1.50 mtrs. Wide upto terrace floor.
3. Protection of Exits by Fire Doors or Pressurisation: Not required.
4. Compartmentation: - Not required.
5. Smoke management: - Not required.
6. Fire Extinguishers: Provided one CO2 type of 4.5 kg capacity and one of ABC type 5 kg capacity ISI mark at each floor.
7. First Aid hose reel: Not required but provided
8. Automatic Fire Detection and alarm system: - Not required.
9. MOEFA : Provided one electric bell to use in emergency.
10. P.A.System: - Not required.
11. Automatic Sprinkler System: Not provided as the area of the basement is 182 sq m.
12. Internal Hydrants/Yard hydrants: - Not required but provided with hose boxes, delivery hoses and branch pipes.
13. Pumping arrangements: Not required but provided having main fire pump of 180 LPM.
14. Captive Water Storage: Not required but provided of 3000 ltrs. capacity.
15. Exit Signage: Provided Exit signs and floor marking on both the floors.
16. Provision of lifts: - Not required.
17. Standby Power Supply: - Not required.
18. Refuge Area: - Not required.
19. Fire Control Room: - Not required.
20. Special Fire Protection for special fire risk: - Not required.

All the aforesaid systems were checked and their performance was found satisfactory at the time of inspection.

In view of the satisfactory performance of the fire safety arrangements as per NBC Part-IV, fire safety certificate (NOC) is recommended. Accordingly draft Fire Safety Certificate in placed on the file for approval and signature please.

Vijay Bahadur 3.8.11
Div. Officer (LN)

Dy.CFO-I
[Handwritten signatures and initials]
5/8
5/8
FT
M.P.M.

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE

{See sub-rule (1) of rule 35}

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.**

No. F6/DFS/MS/2011/1998

Dated: 16/08/11

FIRE SAFETY CERTIFICATE

Certified that the **Bal Bhawan Public School at A-Block, Swasthya Vihar, Delhi-110092 comprised of basement, ground and 1st floor owned/occupied** by Lagan Kala Upvan (Regd.) An Educational and Cultural Society have complied with the fire prevention and fire safety requirements in accordance the guide lines issued by the Director of Education, Govt. of NCT of Dated 01-03-11 and verified by the officer concerned of Delhi Fire Service in the presence of Shri Kunal Gupta, the Principal of the School and that the building/premises is fit for occupancy **class Group-B (Educational Building)** with effect from the issuance of this certificate for a period of three years, subject to condition as mentioned below.

Issued on 16/08/11 at New Delhi by



CHIEF FIRE OFFICER
DELHI FIRE SERVICE.

Copy to:-

1. The Principal, Bal Bhawan Public School, A-Block Swasthya Vihar, Delhi-110 092.
2. Director of Education, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate

- a. All the Fire safety and means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety r means of evacuation facilities rendering non functional shall be responsibility of the management.
- b. Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.