

Ref: - Letter No -112- dated -112- (On 14/7/96)

with ref. above quoted letter, reply letter is put up for perusal & sign, if approved.

Submitted Please.

Wshank
10/3/11

DD (BOP) A/Ref
11/3/11

D/Ref a
14/3

MS ce4

Ref: - Letter No DHO/CZ/2011/199 dt 26/5/11

with ref. above quoted letter, it is submitted that this deptt. have issued NOC vide letter No. FB/MS/O&S/EM/2006/526 dt. 3.3.06 on the bases of fire protection measures as mentioned below.

1. Hose Reels — Provided (Restaurant area)
2. Down Corner System — Not required.
3. Automatic sprinkler System — Not required.
4. Manual fire alarm (MFCP) — Provided. (restaurant area)
5. Terrace tank (OHT) — Provided (2500 ltrs)
6. Fire Pump — Provided (225 lpm)
7. Fire Extinguishers — Provided (Co₂ ABC Type)
8. Access — Available (4-5 mtr)
9. Emergency light battery backup — Provided.
10. Exit Signs — Provided
11. Emergency supply — Provided DG set
12. means of Escape — Provided (2 Exits)

13. Smoke Venting — Exhaust fan provided

14. Concealed type Electric wiring & MCB/EICB — Provided.

Further the restaurant premises have been re-inspected by ADD (NP) on 16/6 & again on 4-7-11. In the presence of manager & other tech. staff and observed that

There is no additional construction have been made for which NOC was issued by this dept vide letter dated 3-3-06.

All the fire protection arrangements as stated on page have been checked and found in good working condition at the time of inspection.

In view of the above, renewal of fire safety certificate is recommended. Accordingly draft letter is placed on file for approval/sign.

Submitted please.

Gurumukh
2/8/11

DO CBEP
Atul
4/8/11

DCR/1
S
8/8

CF/ No. of exits ?

CF
5/8

Syef

DO CBEP
Atul
9/16

ADD/NP/GURUMUKH

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001


No. F6/OFS/MS/EH/2011/2001

Dated 17/08/11

FIRE SAFETY CERTIFICATE

Certified that the M/S China Pearl Restt. A - 31, Kailash Colony, New Delhi. The Restaurant is being run at the ground floor of the bldg. which comprises ground & three upper floors was granted NOC by this deptt. vide letter No. F6 / DFS / MS / EH / 2006 / 526 dated 3-3-2006. The premises was re-inspected by the officer concerned of this department on 4-7-2011 in the presence of Manager & other tech. staff and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy with effect from 17-8-2011 for a period of three year in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 17/08/11 at New Delhi.


Tbje
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. M/S China Peral Restt.
A - 31, Kailash Colony,
New Delhi.
2. Dy. Health Officer
Health Department Central Zone
Lajpat Nagar, New Delhi.




16/8

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.