

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F 6 / DFS / MS / 2011 / GH / 2224

Dated 12/09/11

FIRE SAFETY CERTIFICATE

Certified that the Hotel Ganga Azure located at E 58 Greater Kailash-I, New Delhi comprised of Basement, Ground + 3 upper floors was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2008 / 2376 dated 21.08.2008. The premise was re-inspected by the officer concerned of this department on 15.08.2011 and found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Sub-Division A-I, Lodging or Rooming House of Group A with effect from 12/09/11 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 12/09/11 at New Delhi

Yours faithfully

  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic) 1<sup>st</sup> Floor, Police Station Defense Colony New Delhi
2. Hotel Ganga Azure located at E 58 Greater Kailash-I New Delhi

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : Ganga Agave GH. E, 58 Greater Kailash-I N. Delhi.
2. Type of Occupancy : Residential S. Div. AE Lodging or Rooming House
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. FG/DFSI/MS/GH/2008/2376 Dated: 21.8.2008
5. Fire Safety directives letter No : Not given
6. Date of inspection : 15.8.11
7. Name of the Inspecting Officers : S.S. Kaushik Asstt Div. Officer
8. Name and designation of officers from the building side : 2 Basement + Ground + 3 Upper floor  
Yesh Pal Manager
9. Year of Construction : 1983
10. Applicant's letter No. : 31412/AdhLP/HC (H) dt 4/7/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	13mhr	30mhr	MR
	• Gate width	NR	—	MR
	• Width of internal road	NR		MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases		2.4	
	• Upper Floors		Two Staircases	MR
	• Basements		Three	MR
	b. Width of staircases			
	• Upper Floors	125cms as per IS 801	110cms X 2	MR
	• Basements		175cm 120cm 170cm	MR
	c. Protection of exits			
	• Fire check door	NR		
	• Pressurization	NR		
	e. No. of continuous staircases to terrace		2 Two	
	g. Width of Corridor	NR	4' NR	NR
	h. Door Size	NR	NR	MR

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NR	NR	
		NR	NR	
		NR	NR	
		NR	NR	
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust fan given NG	NR NR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ISI marked	12 CO2 Type & ABC Yes	NR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	One at each floor 30 m hf reel 5 mm reel	NR NR NR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NR	NR	
		NR	NR	
		NR	NR	
		NR	NR	
		NR	NR	
8	<b>MOEFA</b>	Required	provided	NR
9	<b>Public Address System.</b>	NR	N.P	
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	provided	NR

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NR	NP	NR
		NR	NP	NR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NR	NP	NR
		NR	NP	NR
		NR	NP	NR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NR	NP	NR
		NR	NP	NR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		Requind	450LPM	
		40mhr	40 mhr	
		one	one	
			180LPM	
		NR	NP	NR
		NR	NP	NR
		Auto Starting	Yes	NR
		AS given above	AS given above	NR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	NR	NP	NP
		NR	NP	NP

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	✓	✓	✓
15	Exit Signage.	10,000 Ltr Required	10,000 Ltr Provided	MR
16	Provision of Lifts.	NR		
	• Pressurization of Lift Shaft	NR	NR	
	• Pressurization of Lift lobby	NR	NR	
	• Communication In lift Car	NR	NR	
	• Fireman's Grounding Switch	NR	NR	
	• Lift Signage	NR	NR	
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19	Fire Control Room			
	• Detector System Panel	NR	NR	
	• Flow Switch Panel	NR	NR	
	• PA System Panel	NR		
	• Batter backup	NR		
	• Building Floor Plans	NR		
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR NR	NR NR	NR NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Kaushik  
Signature of the Inspecting Officer

Name

Name S-S-Kaushik

Designation

Designation Asst. Inv. Officer