

No. F6/DFS/MS/EH/2011/2236

Dated : 14/09/11

FIRE SAFETY CERTIFICATE

Certified that the **PIND BALLUCHI, The Village Restaurant**, J.S. Hospitality Services (P) Ltd., FA-9,10,11, Unitech Metro Walk, Sector-10, Rohini, Delhi-110085, the building is consist of ground plus one upper floor and situated in Amusement Park premises and restaurant is running at first floor only, was issued NOC vide this office letter No. F.6/DFS/MS/EH/2008/2187 dated 30.07.2008. The premises was re-inspected by the Officers concerned of this department on 25.08.2011 in the presence of Shri Rakesh Rawat, AGM and observed that all the fire safety and fire prevention arrangement as provided in the premises is found in good working condition and there is no additional construction. The premises have therefore deemed complied with requirements under Rule 33 of Delhi Fire Service Rules, 2010 and building/ premises is fit for occupancy under ASSEMBLY class with effect from 14/09/11 for a period of **3 (three)** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the condition under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/09/11 at New Delhi by



**DIRECTOR
DELHI FIRE SERVICE**



Director
PIND BALLUCHI, The Village Restaurant,
J.S. Hospitality Services (P) Ltd.,
FA-9,10,11, Unitech Metro Walk,
Sector-10, Rohini,
Delhi-110 085.

Copy to :

The Deputy Health Officer,
Municipal Corporation of Delhi,
Health Department, Rohini Zone,
Sector-5, Rohini, Delhi.

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

INSPECTION REPORT

- 1 Name & address of the building Kind Baluchi The Village Restaurant
- 2 Type of Occupancy Restaurant F.A. 9, 10, 11 - Unitach Metro walk
- 3 Type of case Unitach Metro walk
- 4 Details of previous NOC F-6 / OFS / MS / EM / 2008 / 2137 dated 30.7.08
- 5 Fire safety directives letter No ---
- 6 Date of inspection 25.08.11
- 7 Name of the inspecting Officers : R.K. Dahiygo A90
- 8 Name and designation of officers ---
from the building side
- 9 Year of construction 2007
- 10 Applicant's letter No. NIL dated 23-6-11

S. NO	Minimum Standards on fire prevention and fire safety U/R 33	NBe Requirement	Provided at site	Remarks MR / NMR
1 Access to building				
	1) Road width	2)	<u>6 meter</u>	<u>6 meter</u>
	Gate width	3)		
	Width of internal road			
2 Number, width Type & arrangement of exits				
	a. Number of staircases	<u>Two</u>	<u>Two 2 meter</u>	<u>MR</u>
	1 Upper floors			
	2 basements	<u>N.A</u>		
	b Width of staircase			
	1 Upper floors	<u>2 meter</u>	<u>Two meter</u>	<u>MR</u>
	2 basements			
	c Protection of exits	<u>NA</u>		
	1 Fire check door			
	2 Pressurization			
	e No of continuous staircase to terrace			
	g. Width of corridor	<u>NA</u>		
	h. Door size	<u>1.50 meter</u>	<u>1.50 meter</u>	<u>2.5 meter MR</u>
3 Compartmentation.				
	1 Fire check door			
	2 Sealing of electrical shafts			
	3 Fire Rating of shaft door			
	4. water curtain			
	5. Fire dampers			
4 Smoke Management system.				
		<u>---</u>	<u>Provided</u>	<u>MR</u>
	basement			
	upper floors	<u>Provided</u>	<u>in the restaurant</u>	<u>MR</u>

5	Fire Extinguishers				
	total numbers			4 NOS.	
	Types			DEP. 4 NOS	
	IS marking			LI - 15L Mark	M/R
6	First-Aid Hose Reels.				
	total numbers on each floor	One		one	MR
	Length of Hose reel hose	-		30 meter	MR
	Nozzle Diameter			5 mm	MR
7	Automatic fire detection and alarming system			Provided	
	Type of detectors			Smoke	MR
	location of Main Panel				
	location of Repeater panel				
	Alternate source of power				
	hooter's location				
8	MOEFA			Provided	MR
9	Public Address System.			Provided	MR
10	Automatic Sprinkler System.			Provided	MR
	basement	—		(in the Restaurant)	
	upper floors:	—			
	sprinkler above false ceiling				
11	Internal Hydrants			NA.	
	Size of riser/down-corner				
	Number of Hydrants per floor				
	hose Box			NA	
12	Yard Hydrants.				
	total number of hydrants				
	house box				
13	Pumping arrangements				
	1. Ground level	NA.			
	a. Discharge of main Pump				
	b. Head of main pump				
	c. Number of main pumps				
	d. jockey pump out put				
	e. jockey pump head				
	f. Standby Pump output				
	g. Standby Pump head				
	h. Auto Starting/Manual stopping				
	pump house access				
	2. Terrace level				
	a. Discharge of pump	Main	450 LPM		MR
	b. head of the pump	Socket	180 LPM		MR
	c. Power supply				
	d. Auto starting of pump			yes	MR
	Captive water storage for fire fighting				
14	fighting				
	1. Underground tank capacity	NA.			
	a. Draw off connection				
	b. fire service inlet				
	c. Access to tank				
	Over head tank Capacity			10,500 Ltrs	MR
15	Exit Signage.				
16	Provision of lifts.				

	a. Pressurization of lift shaft b. pressurization of lift lobby c. communication in lift car d. Fireman's grounding switch e. Lift signage	NA		
17	Standby power supply	N.A.		
18	Refuge Area.	NA		
	total area location			
19	Fire control room	NA		
	a. detector system Panel b. Flow switch Panel c. PA system Panel d. Batter backup e. Building floor plans			
20	Special Fire Protection systems for protection of special risks, if any:	NA		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.~~

Signature of the inspecting officer	R.K. Dehija
Name	Asoo
Designation	_____

CF/O
Jitendra
 13/9

Ash Sho
 14/9