


NO.F6/DFS/MS/2011/ 2146

Dated: 02/09/11

FIRE SAFETY CERTIFICATE

Certified that **Raj Modern Public School** located at **F- Block, Hari Nagar Extn, Part-II, Badarpur, New Delhi** comprised of **ground floor and one upper floor** was granted NOC by this department vide letter No. F.6/DFS/MS/2006/3730 dated 21-12-2006. The premises was re-inspected by the officer concerned of this department on 08-08-2011 in the presence of Mr. Ravi, Chairman of the school and found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with the guidelines of Directorate of Education vide circular dated 17-01-2005 and that the premises / building is fit for occupancy class **Educational (School building)** with effect from 02/09/11 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 02/09/11 at New Delhi by.


Chief Fire Officer
Delhi fire service

Copy to:-

1. The Director of Education, Govt .of NCT of Delhi, Old secretariat, Delhi
2. The Head Mistress, Raj Modern Public School, F- Block, Hari Nagar Extn, Part-II, Badarpur, New Delhi.

Conditions for the validity of fire safety certificate


- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in


With reference above quoted letter received from Uma Balasubramaniam, Head Mistress, Raj Modern Public School (Senior Secondary), F-Block, Hari Nagar Ext., Part-II, Badarpur, New Delhi regarding renewal of fire safety certificate in respect of Raj Modern Public School (Senior Secondary), F-Block, Hari Nagar Ext., Part-II, Badarpur, New Delhi.

The aforesaid school premises have been inspected by the undersigned alongwith Mr. Ravi, Chaiman of the school on 08-08-2011 to verify the provision of fire safety arrangements as per guidelines of Directorate of Education vide circular dated 17-01-2005. The said school premises is comprised of ground and one upper floor. The school is running 13 class rooms at ground floor and 15 class rooms at first floor. Details of fire safety arrangements are as under:-

1. Access:- The school premises is located on a road of sufficient width and approachable to the fire engines.
2. Number, Width, type & arrangement of exits:- 02 entrance / exit gates of sufficient width found provided. 02 staircases having width 1.5 mts each found provided from ground floor to terrace floor.
3. Protection of exits by means of fire check door and or pressurization:- Not required.
4. Compartmentation:- Not required
5. Smoke management system:- Not required.
6. Fire extinguishers:- Two ABC type fire extinguishers of 5 Kg capacity each and two water CO₂ type fire extinguishers of 9 lts capacity each found provided at each floor of the building and functional.
7. First aid hose reel:- Two number of 30 mts length first aid hose reel having a bore of 20 mm terminating into shut off type nozzle of 5 mm outlet found provided at each floor and found functional.
8. Automatic fire detection & alarming system:- Not required
9. MOEFA:- Not required.
10. Public address system:- Not required
11. Automatic sprinkler system:- Not required.
12. Internal hydrants & yard hydrants:- Not required.
13. Pumping arrangement:- One terrace pump capacity 450 LPM connected with overhead water tank found provided and functional.
14. Captive water storage for fire fighting:- One over head water storage tank capacity 3000 lts found provided and full of water at the time of inspection.
15. Exit signage:- Provided
16. Provision of lifts:- Not applicable..
17. Stand by power supply:- Not required
18. Refuge area:- Not required
19. Fire control room:- Not required.
20. Special fire protection systems for protection of special risk:- One ABC type fire extinguishers capacity 5 Kg found provided near each electric panel.

In view of the satisfactory compliance fire safety arrangements, this department may have no objection for the renewal of fire safety certificate subject to the conditions laid down in the certificate. Accordingly fire safety certificate is prepared and put up for perusal and signature if approved please.

Do (BUP) 
30/8/11


9/8/2011

ADO: M.K. Chaturvedi.