

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110 001

No. *FG/DFS/MS/2011/2256*

Dated: *16/9/2011*

FIRE SAFETY CERTIFICATE

Certified that the building at plot no. J-23, located at Udyog Nagar, Peera Garhi, Delhi, is comprised of basement, ground floor, mezzanine and first floor only was issued NOC vided letter no. *55 (1)/DFS/2006.59* dated *14-02-2006*. The premises was re-inspected by the officer concerned of this department along with Sh. O.P. Monga, and observed that the owner/occupier have deemed complied with the fire prevention and fire safety requirements under Rule 33 of the Delhi Fire Service Rules 2010 and found that all the fire prevention and fire safety requirements are maintained in good working condition and there is no additional construction and therefore, the premises is fit for occupancy class Group C (a) (ii) hence, NOC is renewed w. e. f. *16/9/11* for a period of three years in accordance with Rule 35 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on *16/9/11* at New Delhi by

[Signature]
Chief Fire Officer
Delhi Fire Service

Copy to :-

1- Sh. O.P. Monga, J-23, Udyog Nagar, Rohtak Road, New Delhi.

CONDITIONS FOR THE VALIDITY OF FIRE SAFETY CERTIFICATE

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all time. The owner/occupier shall submit a declaration every year in form "K" provided in the first shedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation, with regards to construction etc shall be verified the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building Bye-Laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.

May kindly peruse letter no. dated received J-23, Udyog Nagar, Peera Garhi, Delhi where in renewal of NOC is requested this restaurant has already been issued NOC's number of types hence the recommendation are made on old lines. Accordingly, inspection was carried out by D.O. (Moti Nagar) of the restaurant was also present at the time of inspection.

1. Name & address of the building : J-23, Udyog Nagar, Peera Garhi, Delhi Bagh, New Delhi
2. Type of Occupancy : Industrial (G-19)ii)
3. Type of Case : Renewal
4. Details of previous NOC : Letter no. F5/J/DFS/2006/59 dated 14/2/2006
5. Fire Safety directives letter No. : F-5(J) DFS/2005/491 dated 12/10/2005
6. Date of inspection : 14/08/2011
7. Name of the Inspecting Officers : Division Officer Sunil Chowdhary
8. Name and designation of officers
 From the building side : Sh. O.P. Monga Owner
9. Year of Construction : No record available
10. Applicant's letter No. : Nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	03 mtrs	45 feet	Recommended
	• Gate width	5 mtr	5 mtr	Recommended
	• Width of internal road		Set back	Recommended
2.	Number, Width, Type & Arrangement of Exits			

a. Number of staircases	<ul style="list-style-type: none"> Upper Floors 	Two	Two	Recommended	
		Two	Two	Recommended	
	<ul style="list-style-type: none"> Basement 				
		1.5 mtr each	1.5 mtr each	Recommended	
	<ul style="list-style-type: none"> Basement 	1.5 mtr each	1.5 mtr each	Recommended	
	c. Protection of exits	<ul style="list-style-type: none"> Fire check door 	N/R	Provided	Recommended
			N/R	N/R	
		<ul style="list-style-type: none"> Pressurization 			
	d. No. of continuous staircases to terrace			N.A	Recommended
1.5 mtrs.					
e. Width of Corridor					
f. Door size	1 mtrs	1.25 mtr		Recommended	
3.	Compartmentation.				
<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Basement	Provided		Recommended	
	N.A.	No Shafts		Recommended	
	N.A.	N.R.		Recommended	
	N.A.	N/R		Recommended	
	N.A.	N/R		Recommended	
4.	Smoke Management System.				
<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour N.R.	Exhaust Fan		Recommended	
		Exhaust Fan			
5.	Fire Extinguishers				
<ul style="list-style-type: none"> Total numbers 	A.B.C.	10		Recommended	

	<ul style="list-style-type: none"> Types IS marking 	ISI marked	ABC Type	
			ISI marked	
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 		01	Recommended
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 m.m	
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/R	N.R.	Recommended
	<ul style="list-style-type: none"> Location of Main Panel 	N/R	N.R.	Recommended
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/R	N.R.	Recommended
	<ul style="list-style-type: none"> Alternate source of power 	N/R	N.R.	Recommended
	<ul style="list-style-type: none"> Hooter's Location 	N/R	Provided on each Each floor	Recommended -
8.	MOEFA		N/R	
9.	Public Address System.		N.R.	
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 		Provided	
	<ul style="list-style-type: none"> Upper Floor 	N/R	N/R	Recommended
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N.A.	N/R	Recommended
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/R	N/R	Recommended

	<ul style="list-style-type: none"> Number of hydrants per floor 	N/R	N/R	
	<ul style="list-style-type: none"> Hose Box 	N/R	N/R	
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/R	N/R	Recommended
	<ul style="list-style-type: none"> Hose Box 	N/R	N/R	-do-
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	B.B.L. do not safety pump capacity	1620 LPM	Recommended being old case
	➤ Head of Main pump	B.B.L. do not safety pump capacity	65 mtr	
	➤ Number of main pumps	B.B.L. do not safety pump capacity	one	
	➤ Jockey Pump out put	B.B.L. do not safety pump capacity.	180 L.P.M.	
	➤ Jockey pump head	B.B.L. do not safety pump capacity	65 mtr	
	➤ Standby pump out put	B.B.L. do not safety pump capacity	N/R	
	➤ Standby pump Head	B.B.L. do not safety pump capacity.	N/R	
	➤ Auto Starting/Manual stopping	B.B.L. do not safety pump capacity	Manual	
	➤ Pump Hose Access	B.B.L. do not safety pump capacity	Accessible	Recommended
	Terrace level			
	➤ Discharge of pump	N/R	N/R	Recommended
	➤ Head of the pump	N/R	N/R	Recommended
	➤ Power supply	N.R.	N/R	Recommended
	➤ Auto Starting of pump	N.R.		

☛ **Captive Water Storage for fire fighting.**

	Underground tank capacity	B.B.L. do not safety tank capacity	25000 ltrs	recommended	
		➤ Draw -off connection	B.B.L. do not safety tank capacity	N/R	
		➤ Fire service inlet	N/R	N/P	recommended
		➤ Access to tank	Accessible	Accessible	recommended
		➤ Overhead Tank Capacity	Do not specify	15,000 ltrs	recommended
15	Exit Signage.				
16.	Provision of Lifts				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A.	Not available	Recommended	
		N.R.	Not available	recommended	
		N.R.	Not available	recommended	
		N.R.	Not available	recommended	
		N.R.	Not available	recommended	
17.	Standby power supply	N.R	Provided 65 K.V.A	recommended	
18.	Refuge Area		N.R.		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	Not applicable	N.R.	recommended	
		Not applicable	N.R.	recommended	
19.	Fire Control Room				
	<ul style="list-style-type: none"> ➤ Detector System Panel ➤ Flow Switch Panel ➤ PA system Panel ➤ Batter backup 	N.A.	N/R	recommended	
		N.A.	N/R	recommended	
		N.A.	N/R	recommended	
		N.A.	N/R	recommended	

	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.R.	recommended

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....



Signature of the Inspection Officer

Signature of the Inspection Officer

Name *Sunil Chawdhary*

Name

Designation *D.O. (M-N) MS*

Designation

Seen
MS
16/9

O/C