

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No FS (BA) / DFS / MS / 2011 / 207

Dated 16 / 09 / 11

FIRE SAFETY CERTIFICATE

Certified that the Fire Works Shop No 87/2, Main Arya Samaj Road, Pana Mamur Pur, Narela, Delhi-40 comprised of ground floor only thus below 9 m in height have complied with the fire prevention and fire safety requirements in accordance with guidelines issued by Additional Commissioner of Police (Lic.) and verified by the officer concerned of Delhi Fire Service on 02.09.2011 in the presence of Shri Dinesh Kumar, Owner and the shop is fit for running the trade of Sale and Possession of Fire Works under occupancy Class Fire Works with effect from 16/09/11 for a period of three years.

Issued on 16/09/11 at New Delhi


CHIEF FIRE OFFICER
FOR DIRECTOR
DELHI FIRE SERVICE



Copy to:-

1. Addl. Dy Commissioner of Police (Lic)
First Floor, Police Station, Defence Colony, New Delhi
--- w.r.t. Letter No. (PDQ/16)/2010/124-126/Addl.CP/Lic. (Expl.),
Dated the 3rd January, 2011
2. Shri Dinesh Kumar, Owner,
Shop No 87/2, Main Arya Samaj Road,
Pana Mamurpur, Narela, Delhi-40

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock when the shop is open.
4. Any deviation w.r.t construction etc shall be verified by the concerned building sanctioning authority.
5. This certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : SHRI DINESH KUMAR
Shop No. 87/2, Main Arya Samaj Road, Navels
2. Type of Occupancy : PERMANENT FIRE WORKS
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : N.A. Letter No. _____ Dated _____
5. Fire Safety directives letter No : N.A.
6. Date of inspection : 02/09/2011
7. Name of the Inspecting Officers : SHRI R.K. DAHIYA
8. Name and designation of officers from the building side : N.A.
9. Year of Construction : 1996, (DFW) 16 / 2011 / 37907-09 / Addl. CP / Lic (Exp.H.)
10. Applicant's letter No. : Dated 10.8.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>66 feet</u>		
	• Gate width	<u>ON ROAD</u>		
	• Width of internal road	<u>-</u>		
2	Number, Width, Type & Arrangement of Exits	<u>N.A.</u>		
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			

3	Compartmentation. <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.A.		
4	Smoke Management System. <ul style="list-style-type: none"> • Basements • Upper floors 	N.A.	30 a/c per hour 12 a/c per hour	
5	Fire Extinguishers <ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	3 FIRE EXTINGUISHERS 1 - Water CO ₂ & 2 - ABC Type Yes ISI Marked	
6	First-Aid Hose Reels. <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	N.A.	30 m 5 mm	
7	Automatic fire detection and alarming system. <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.A.		
8	MOEFA	N.A.		
9	Public Address System.	N.A.		
10	Automatic Sprinkler System. <ul style="list-style-type: none"> • Basement 	N.A.		

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants	N.A.		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.	N.A.		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.	N.A.		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/ Manual stopping ➢ Pump House Access • Terrace level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Power Supply ➢ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.	N.A.		
	<ul style="list-style-type: none"> • Underground tank capacity ➢ Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	N.A.		
16	Provision of Lifts.	N.A.		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	N.A.		
18	Refuge Area.	N.A.		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	N.A.		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers

R.K. Dolyu

Signature of the Inspecting Officer

Name *R.K. Dolyu*

Designation *ADD*

~~Signature of the Inspecting Officer~~

~~Name~~

~~Designation~~