

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/2011/2121

Dated : 30/08/11

FIRE SAFETY CERTIFICATE

Certified that the Amusement Park in the name and style of M/s. Fun 'N' Food Village, Polo Amusement Park Ltd. Located at Kapashera, New Delhi - 110037 comprised of ground floor was granted NOC by this department vide letter No. F6/DFS/MS/EH/2007/139 dated 16-01-2007. The premises was re-inspected by the officer concerned of this department on 24-08-2011 in the presence of Mr. Mahinder Sharma and found that the said amusement park building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy with effect from 30/08/11 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service subject to conditions printed overleaf.

Issued 30/08/11 at New Delhi by.



(A. K. SHARMA)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director,
Fun N Food Village,
(M/s. Polo Amusement Park Ltd.),
Old Delhi Gurgaon Road,
Kapashera, New Delhi - 110037
2. The Addl. Commissioner of Police (Lic.),
1st Floor, PS Defence Colony,
New Delhi - 110049

Following fire safety directives must be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of Building Bye-Law.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.