

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2011/2300

Dated 23/09/11

FIRE SAFETY CERTIFICATE

Certified that the building of **Andhra Education Society, Middle School, Gazipur, Delhi-110096** comprised of ground floors only and having total 15 rooms including one Entry & Exit Administrative offices, Library, computer Lab etc. owned / occupied by **Andhra Education Society** have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the director of Education, Govt. of NCT of Delhi, Dated 01-03-2011 and verified by the officers concerned of Fire Service on 17-08-11 in the presence of **Sh. Jagdish Principal, with other staff** and that the building is fit for occupancy class "**Educational**" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 23/09/11 at New Delhi.



CHIEF FIRE OFFICER  
DELHI FIRE SERVICE.

Copy to:-

1. The Manager, Andhra Education Society, Middle School, Gazipur, Delhi-110096.
2. Director of Educational, Govt. of NCT of Delhi, Old Secret rate, Delhi-54.

Conditions for the validity of Fire Safety Certificate

- a. All the means of escape shall be kept free of all type of obstruction all the time.
- b. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- c. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- d. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- e. Basement shall be used as per BBL.
- f. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- g. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building: Andhra Education Society Middle School
2. Type of Occupancy: School - K.M. 149, GAZI PUR, Village Belur
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. \_\_\_\_\_ Dated: \_\_\_\_\_
5. Fire Safety directives letter No: NEW CASE
6. Date of inspection: \_\_\_\_\_
7. Name of the Inspecting Officers: D.O. VIJAY BAKADUR
8. Name and designation of officers from the building side: SH. S. NAZEER JAN, Hon. Manager
9. Year of Construction: \_\_\_\_\_
10. Applicant's letter No. AES/GZ/LL-1/Sept 2010 dt 15.9.10

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width		30mtrs	
	• Gate width		6mtrs	
	• Width of internal road		Main Rd	
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
a.	Number of staircases	School Buildings only of G. Floor		
	• Upper Floors	-  -	-  -	
	• Basements	-  -	-  -	
b.	Width of staircases	Not Required.		
	• Upper Floors	-  -	-  -	
	• Basements	-  -	-  -	
c.	Protection of exits	Not Required		
	• Fire check door	-  -	-  -	
	• Pressurization	-  -	-  -	
e.	No. of continuous staircases to terrace	-  -	-  -	
g.	Width of Corridor	Not Required		
		-  -	-  -	
h.	Door Size	-  -	-  -	

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		Not Required	
			-1-	
			-1-	
			-12-	
			-11-	
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Not Required	
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers Foam 949-1HP</li> <li>• Types 5.1kg - ABC - 5HP</li> <li>• IS marking 5.1kg - CO2 2HP</li> </ul>	ISI marked	4.5.1kg - ABC 5kg ABC CO2 ✓ CO	1 HP ✓ CO
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	Not Required	
			-1-	
			-1-	
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		Not Required	
			-1-	
			-1-	
			-1-	
			-1-	
8	<b>MOEFA</b>			
			Not Required	
9	<b>Public Address System.</b>			
			Not Required	
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>		Not Required	

	<ul style="list-style-type: none"><li>• Upper Floor</li><li>• Sprinkler above false ceiling</li></ul>	Not Required	
11	<b>Internal Hydrants</b>		
	<ul style="list-style-type: none"><li>• Size of riser/down-comer</li><li>• Number of hydrants per floor</li><li>• Hose Box</li></ul>	Not Required	
12	<b>Yard Hydrants.</b>	Not Required	
	<ul style="list-style-type: none"><li>• Total number of hydrants</li><li>• Hose Box</li></ul>	— 1	
13	<b>Pumping Arrangements.</b>	Not Required	
	<ul style="list-style-type: none"><li>• Ground Level<ul style="list-style-type: none"><li>➤ Discharge of main Pump</li><li>➤ Head of Main pump</li><li>➤ Number of main pumps</li><li>➤ Jockey Pump out put</li><li>➤ Jockey pump head</li><li>➤ Standby Pump out put</li><li>➤ Standby Pump Head</li><li>➤ Auto Starting/ Manual stopping</li><li>➤ Pump House Access</li></ul></li><li>• Terrace level<ul style="list-style-type: none"><li>➤ Discharge of pump</li><li>➤ Head of the pump</li><li>➤ Power Supply</li><li>➤ Auto Starting of pump</li></ul></li></ul>	Not Required	
14	<b>Captive Water Storage for fire fighting.</b>		
	<ul style="list-style-type: none"><li>• Underground tank capacity</li><li>➤ Draw-off connection</li></ul>	Not Required	

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	not Required		
15	Exit Signage.	not Required		
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA		
17	Standby power supply	SIVA - one		
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	not Required		
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	not Required		
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *Vbd.*  
Name *VIJAY BAHADUR*  
Designation *D.O. FIRE*

Signature of the Inspecting Officer *VBP*  
Name *VIJAY BAHADUR*  
Designation *D.O FIRE*