

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001

No: F 6/DFS/MS/2011/ EH/ 2294

Dated:- 23/09/11

FIRE SAFETY CERTIFICATE

Certified that the Dwarika Restaurant, 3-F Kamla Nagar  
Delhi 7 located at Kamla Nagar  
Delhi-7 comprised of Ground floor only occupied  
by Dwarika Restaurant (A Unit of Chandhok Syndicate) was issued NOC vide this office letter  
No. F.6/DFS/MS/EH/08/3003 Dated: 03-11-08. The premises was re-inspected by the  
officer concerned of this department on 29/9/11 and observed that all the fire  
prevention and fire safety arrangements as provided in the premises found in good working  
condition. The premises have therefore, deemed complied with the requirement under Rule 33  
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class  
Assembly Sub-Div. D-5 with effect from 23/09/11 for a period of  
03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on 23/09/11 at New Delhi.



Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Dy. Health officer  
M.C.D. Civil Lines Zone  
Raj Park Road  
Delhi
2. The Manager,  
Dwarika Restaurant  
3-F, Kamla Nagar  
Delhi 7.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : DWARKA RESTAURANT, 3<sup>F</sup> KAMLA NAGAR, DELHI.
2. Type of Occupancy : RESTAURANT.
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. FG/DFS/MS/EH/08/3003 Dated: 3/11/2008
5. Fire Safety directives letter No : NO
6. Date of inspection : 5/9/11
7. Name of the Inspecting Officers : VIPIN KENTAL
8. Name and designation of officers from the building side : sn - Asay manager.
9. Year of Construction : \_\_\_\_\_
10. Applicant's letter No. : NAI BT NAI.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width		<u>motorable road. M/R</u>	
	• Gate width		<u>N/A</u>	
	• Width of internal road		<u>N/A</u>	
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases		<u>located on 6<sup>F</sup> only</u>	
	• Upper Floors		/	
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size		<u>N/A being old case.</u>	



3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<i>Not required</i>		
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	<i>N.A. being old case.</i>	
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ISI marked	6 NO. 3 DC type 5 kg. 3 CO2 type 4.5 kg	M.R
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	1 on 4/F P P	M.R M.R
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	<i>Not required.</i>		
8	<b>MOEFA</b>	<i>Required</i>	<i>Provided</i>	<i>M/R</i>
9	<b>Public Address System.</b>	<i>Not required</i>		
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	<i>No basement</i>		<i>N.A.</i>

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			N.A.
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			Not required
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			Not required.
		225 LPM	225 LPM	M/R
		main + D.G. jet	15 mtr. provided.	M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>			Not required.

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N.R.		
15	Exit Signage.	required.		
16	Provision of Lifts.	not provided.		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	Standby power supply	Required	provided 63.5 kVA	M/R.
18	Refuge Area.	not required		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	Fire Control Room	not required.		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	no special risk except oil in kitchen.	DLP type fire ext. provided	M/R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

*Vipin Kental*

Signature of the Inspecting Officer

Name *VIPIN KENTAL*

Designation *DO NW*