

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/24/2322

Dated:- 26/09/11

FIRE SAFETY CERTIFICATE

Certified that the M/s Gola Bizzler Restaurant, GA-11 & 12 Metroville Adventure Island Sect-10 Rohini located at Metroville Adventure Island Sect-10, Rohini Delhi comprised of second floor only occupied by Sh. Mohit Wadhwa (Gola Bizzler Restaurant) was issued NOC vide this office letter No. F-6/DFS/MS/2008/2268 Dated: 7/8/08. The premises was re-inspected by the officer concerned of this department on 9/9/11 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class Assembly Sub. Div. D-5 with effect from 26/09/11 for a period of 03 years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/09/11 at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer, MCD
Health Deptt - Rohini zone,
Sect- 5 Rohini
Delhi 110085.
2. The Manager
M/s Gola Bizzler Rest.
GA-11 & 12, Metroville Adventure
Island Sect-10, Rohini Delhi.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Golla Si 33/2, GA-11 P/12, metro walk
2. Type of Occupancy : Restaurant Adventure Island Sec-10,
3. Type of Case : New Case/ Renewal Release
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2008/2268 Dated: 7/8/08
5. Fire Safety directives letter No : no
6. Date of inspection : 9/9/11
7. Name of the Inspecting Officers : Vijay Kantal.
8. Name and designation of officers from the building side : Mr. Shashi Bhushan manager
9. Year of Construction : 2006
10. Applicant's letter No. : MHO/RZ/2011/305 dt-12-8-11 from Dy health officer

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr provided	M/R ✓
	• Gate width	5 mtr	5 mtr provided	M/R ✓
	• Width of internal road	6 mtr	6 mtr provided	M/R ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			
		Exit -	1.30 mtr 1.20 mtr 0.90 mtr	M/R

Two Exits being old case

3	Compartmentation.		not required	not provided	-
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			/	
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N.A. provided		M/R
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	2 no 1 water CO2 9kg 1 DCP 5kg/CO2 ISI marked 45kg	5 no. DCP type 5kg. 1 water CO2 9kg yes		M/R
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 m 5 mm	one provided yes yes		M/R
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		not required	provided	-
				/	
8	MOEFA		require.	provided	M/R
9	Public Address System.		not required		
10	Automatic Sprinkler System.		not required	provided	
	<ul style="list-style-type: none"> • Basement 		/	at site/Restaurant.	

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants	not required.		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		4" internal hydrant provided	
			provided	
12	Yard Hydrants.	not required.		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.	provided from main pump of house - Ambulance - main Park		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➢ Discharge of main Pump ➢ Head of Main pump ➢ Number of main pumps ➢ Jockey Pump out put ➢ Jockey pump head ➢ Standby Pump out put ➢ Standby Pump Head ➢ Auto Starting/ Manual stopping ➢ Pump House Access • Terrace level <ul style="list-style-type: none"> ➢ Discharge of pump ➢ Head of the pump ➢ Power Supply ➢ Auto Starting of pump 	one pump of 225 LPM	4500 LPM 60 mtr	M/R
			160 LPM 60 mtr	
			4500 LPM 60 mtr need	
			yes	
			P	
		225 LPM	above capacity of pump provided	M/R
14	Captive Water Storage for fire fighting.	not required		
	<ul style="list-style-type: none"> • Underground tank capacity ➢ Draw-off connection 		1,25,000 ltr provided	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	not required		
		2500 Mts	Via tank provided	M/R
15	Exit Signage.		Provided.	
16	Provision of Lifts.	not provided.		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/		
17	Standby power supply	required	Provided.	M/R
18	Refuge Area.	not required		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/		
19	Fire Control Room	not required		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/		
20	Special Fire Protection Systems for Protection of special Risks, if any:		No such risk except kitchen for which DCP type fire ext. provided	M/R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Yipin Kental
Signature of the Inspecting Officer

Name *YIPIN KENTAL*

Designation *DO, NW*