

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFSS/MS/2011/2315

Dated: 26/09/2011

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidhyalaya is comprised of Ground + 01 upper floor building thus below 09 mtrs, located at Ramesh Nagar, New Delhi 110015 have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 23/08/2011 in the presence of Principal Smt Pratibha Sapra and that the building premises is fit for occupancy of Group B Educational Building Class Sub Div. B-1 (Schools upto Senior Secondary level) with effect from 26/09/2011 for a period of three years, subject to conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities non-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 26/09/11 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. The Principal, Sarvodaya Kanya Vidhyalaya, Ramesh Nagar, New Delhi, 110015
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidhyalaya, Ramesh Nagar, Delhi
2. Type of Occupancy : School (G+1)
3. Type of Case : New Case ~~Renewal~~
4. Details of previous NOC : Letter No. NIL Date: NIL
5. Fire Safety directives letter No. : As per Director of Education Letter dttd 01/03/11
6. Date of inspection : 30/8/11
7. Name of the Inspecting Officers : ADD S. S. Tuli
8. Name and designation of officers from the building side : Principal Smt Pratibha Sapra
9. Year of Construction : -
10. Applicant's letter No. : SKV/RN/2011/311 dttd 19/5/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks Y/N/NR
1	Access to building			
	• Road width	6M	6M	NR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Four	NR
	• Upper floors	Two	Four	NR
	• Basements	—	—	—

	b. Width of staircases	1.5M	150, 150, 127 & 122 cms	MR
	• Upper Floors	1.5M	— " —	MR
	• Basements	—	—	—
	c. Protection of exits	NR	NR	NA
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	—	—	—
3.	Compartmentation.	NR	NP	NA
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System.	NR	NP	NA
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—

5/4

Fire Extinguishers

	• Total numbers		14	MR	
	• Types	ISI marked	ABC	MR	
	• IS marking		ISI	MR	
6	First-Aid Hose Reels:		NR	NP	NA
	• Total numbers on each floor		—	—	
	• Length of hose reel hose	30 m	—	—	
	• Nozzle diameter	5 mm	—	—	
7	Automatic fire detection and alarming system:		NR	NP	NA
	• Type of detectors		—	—	—
	• Location of Main Panel		—	—	—
	• Location of Repeater Panel		—	—	—
	• Alternate source of power		—	—	—
	• Hooters' Location		—	—	—
8	MOEFA		NR	NP	NA
9	Public Address System:		NR	NP	NA
10	Automatic Sprinkler System:		NR	NP	NA
	• Basement		—	—	—
	• Upper Floor		—	—	—
	• Sprinkler above false ceiling		—	—	—

11	Internal Hydrants	NR	NP	NA
	• Size of riser down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—
12	Yard Hydrants.	NR	NP	NA
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.	NR	NP	NA
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting Manual stopping	—	—	—
	➤ Pump House Access	—	—	—

	Terrace level	-	-	-
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	-	-	-
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NR	NP	NA
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-
15	Exit Signage.	NR	NR	NA
16	Provision of Lifts.	NR	NP	NA
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication in lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-

17	Standby power supply	NR	NP	NA ³
18	Refuge Area.	NR	NP	NA
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NR	NP	NA
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• P.A. System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. ~~Issue shortcoming was noted at serial numbers.....~~

Signature of the Inspecting Officer

Name

Designation

SSTuli

SSTuli

ADD (MN)

Signature of the Inspecting Officer

Name

Designation

[Signature]

[Signature]