

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS- DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / 9H/2452

Dated 07/10/11

FIRE SAFETY CERTIFICATE

Certified that the Atithi Palace Guest house at 50/4945, Darya Ganj, New Delhi-02 comprised of, Basement + Ground + 02 upper floors was granted NOC by this department vide letter No F 6 / DFS / MS / 2008 / 2976 dated 30.10.2008. The premises was re-inspected by the officer concerned of this department on 27.09.2011 in the presence of Manager Sh. Wilson F. Masih and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from 07/10/11... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/10/11 at New Delhi by



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station, Defence Colony, New Delhi
2. The Owner, Atithi Palace Guest house at 4945/50, Darya Ganj, New Delhi-02

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Building Covered under special area

L. No. F-6/MS/DFS/2001/1795 Dated 29-8-2001

INSPECTION REPORT

1. Name & address of the building: Hotel Atithi Palace, 49/50 Darya Granj, MS
2. Type of Occupancy: Group-A-1, Residential
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No F-6/MS/DFS/GH/08/2976 Dated 30-10-2000
5. Fire Safety directives letter No: F-6/MS/DFS/GH/2000/1999 dt. 2nd 2000 & F-6/MS/DFS/GH/2000/1218 dt. 25th 01. & 01/292 dt 19/27-9-2001
6. Date of inspection: 27-9-2001
7. Name of the Inspecting Officers: A D O - SHYAM LAL
8. Name and designation of officers from the building side: Manager - Sh. Wilson F. Masih (B+Gr+2 upper floors)
9. Year of Construction: 2001, 38 Rooms at G.F., Fl. & Sf.
10. Applicant's letter No: 39352/Addl.CP./H/CH dt. 23-8-2001

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars G.H. Requirement	Provided at site	Remarks
1	Access to building <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 		6m eight (8) mtrs. N/A 02-30 mtrs N/A	MR MR MR
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases		5 Nos	MR
	• Upper Floors	4	2 Nos	MR du
	• Basements	1	3 Nos	MR du
b.	Width of staircases			MR
	• Upper Floors	1.25	1.35 mtrs 90cms	MR du
	• Basements	1.25	1.4 mtrs, 110cm	MR d.
c.	Protection of exits			
	• Fire check door	N/A	-	
	• Pressurization	N/A	-	
e.	No. of continuous staircases to terrace		two	
g.	Width of Corridor	N/A		add ce
h.	Door Size	N/A		add ce

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NR	
			N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NR Exhaust fans N/A	MIR all
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	9 w/CO2 & CO2 ISI marked	9 ABC, CO2, WCO2 yes	MR MIR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one provided provided	MIR MR MIR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A	NR N/A N/A N/A N/A	N/A N/A N/A N/A MIR
8	MOEFA			
			provided	MR
9	Public Address System.			
		N/A	provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Reqn	provided	MR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	NR	N/R	
		N/R		
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	100 mm	M/R
		one	one	M/R
		one	one	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		N/R	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NR		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		N/A		
		450 lts/minute	450 lts/minute	M/R
		40 m	40 m	M/R
		provided	provided	M/R
		provided	provided	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	NR		

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
		10 000 Lts.	10 000 Lts	MR
15	Exit Signage.	stairs/corridor	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
		Provided	Provided	MR
		Provided	Provided	MR
17	Standby power supply		Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A.	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:			
			Nil	

The fire-protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer
Shyam Lal
27/9/2011

Name SHYAM LAL

Designation ACSIT. Divn. Officer