

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / 44 / 235

Dated 28/09/11

FIRE SAFETY CERTIFICATE

Certified that the Guest house Jamia, at 715,716 & 718, behind Jama Masjid, Delhi - 06 comprised of, Ground + 3 upper floors was granted NOC by this department vide letter No F 6 / DFS / MS / 2008 / 2772 dated 01.10.2008. The premises was re-inspected by the officer concerned of this department on 22.09.2011 in the presence of Mr. Mohd. Sultan Hashmi and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" with effect from ..28./09./11... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..28./09./11..... at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

g/r

Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station, Defence Colony, New Delhi.
2. The Owner, (Mohd. Sultan Hashmi) 715, 716, & 718, behind Jama Masjid, Delhi - 06

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Building Covered under special area

No. F-6/ms/DFS/2001/1795 dated 29-8-2001

INSPECTION REPORT

1. Name & address of the building : Jamia Guest House, 715-16 E-718, Behind Jamia Masjid
2. Type of Occupancy : Group-A Residential
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No F-6/ms/DFS/GH/08/2772 dt. 1st 10/08 Dated: 1-10-2001
5. Fire Safety directives letter No F-6/ms/DFS/GH/2000/1999 dt. 2-11-2000 & F-6/ms/DFS/GH/01/12 dt. 22-9-2001
6. Date of inspection : 22-9-2011
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers Mohd. Sultan Hashmi
from the building side : (G + mezo. + 3.) G. House - Ist, IInd, IIIrd (8 Rooms 17
9. Year of Construction : 1950.
10. Applicant's letter No. : 39344/Adh/CP(kic) dt. 23-8-2011.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars Guest House Requirement	Provided at site	Remarks MR/NM
1	Access to building			
	• Road width	-	14	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		Two	MR
	• Upper Floors		Two	
	• Basements		Nil	
	b. Width of staircases		83 cm & 71 cm.	
	• Upper Floors		83 cm & 71 cm.	MR
	• Basements		Nil	
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace		Two	
	g. Width of Corridor		1.15 mts.	
	h. Door Size			

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	5 Nos 2, CO2, 3, W-CO2 WISKY 9 litrs.	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	one 2nd floor. yes yes	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
9	Public Address System.			provided.
10	Automatic Sprinkler System.			N/A.
	<ul style="list-style-type: none"> • Basement 			

old level

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/A	
15	Exit Signage.		2500 ltr.	M/R
16	Provision of Lifts.		Provided.	M/R
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.		N/A	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		N/A	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • P/A System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue short-comings as noted at serial numbers~~..... X.....

Signature of the Inspecting Officer

Name

Designation



Signature of the Inspecting Officer

Name SHYAM LAL

Designation Assill. Divn. Officer