

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F6/DFS/MS/GH/2011/2437

Dated: 05/10/11

FIRE SAFETY CERTIFICATE

Certified that the Hotel Pooja Palace located at 15A/11, WEA, Karol Bagh, New Delhi-110005 comprised of Basement, Ground Floor plus three upper floors, using basement as hall, Ground Floor having reception, two guest rooms, first, second & third each having nine guest rooms respectively (total twenty nine guest rooms) and a pantry & one hall on terrace. Above guest house was issued NOC vide this office letter No.F.6/MS/DFS/GH/2008/2611 dated 16.09.2008 owned/ occupied by Sh. Munish Chawla, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 21.9.2011 in the presence of Sh. Munish Chawla. There is no additional construction and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....05/10/11..... at New Delhi.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Addl. Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No. 37078/Addl.C.P/lic.(H), dated 04.08.2011)
2. Mr. Munish Chawla (Owner)
Hotel Pooja Palace,
15A/11, WEA, Karol Bagh, New Delhi - 110 005.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Hotel Pooja Palace, 15A/11, WEA, Karol Bagh, N.A.-05.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Rehwal
4. Details of Previous NOC : Letter No. F.6/DFs/ms/GH/08/2611 Date 16/09/2008
5. Fire Safety directives letter No : N/A
6. Date of inspection : 21.09.2011
7. Name of Inspecting Officer : A.O.H.L. Aneja, A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Mr. Manish Chawla
9. Year of Construction : Before 2001
10. Applicant's letter No. : 37078/Addl.C.P/Lic(H) dated 04.08.2011.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessable.	09m Approx	MIR
	• Gate width	-	172cm	-
	• Width of internal road	-	5.5m	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	One	One	MIR
	• Upper Floors	-/-	-/-	-/-
	• Basements	-/-	-/-	-/-
	b. Width of staircases	125cm	120cm	Being old case MIR
	• Upper Floor	- do -	- do -	- do -
	• Basements	- do -	122cm	- do -
	c. Protection of exits			
	• Fire check door	N/A	-	-
	• pressurization	N/A	-	-
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	225cm, 148cm	-
	f. Door Size	-	90cm x 205cm	-
3.	Compartmentation			
	• Fire check door	N/A	-	-
	• Sealing of electrical shafts	N/A	Sealed	-
	• Fire Rating of shaft door	N/A	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fan Provided	MIR
	• Upper floors		Natural Ventilation	-

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Two at each floor	Provided	M/R ✓
	• Types	CO ₂ , Water CO ₂	CO ₂ , Water CO ₂	M/R ✓
	• IS marking	ISI marked	Yes	M/R ✓
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	M/R ✓
	• Length of hose reel hose	30 m	- do -	M/R ✓
	• Nozzle diameter	5 mm	- do -	M/R ✓
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. set of 72 KVA	- ✓
	• Hooters' Location	-	-	-
8.	MOEFA			
		Required	Provided	M/R ✓
9.	Public Address System			
		Required	Provided	M/R ✓
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	M/R ✓
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	-	-
	• Number of hydrants per floor	N/A	-	-
	• Hose Box	N/A	-	-
12.	Yard Hydrants			
	• Total number of hydrants	N/A	-	-
	• Hose Box	N/A	-	-
13.	Pumping Arrangements			
	• Ground Level	N/A	-	-
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	—	—
		450 LPM	Provided	M/R
		30m	Provided	M/R
		Required	Provided	M/R
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	—	—
		N/A	—	—
		N/A	Provided	M/R
		N/A	Provided	M/R
		5000L	5000L	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	—	—
		N/A	—	—
		- do -	—	—
		Required	Provided	M/R
		Required	Provided	M/R
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	—	—
		N/A	—	—
		N/A	—	—
		Required	Provided	M/R
		N/A	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ^{Renewal} grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....



Signature of Inspecting Officer

Name H. L. Anuja

Designation Divisional Officer



Signature of Inspecting Officer

Name P. S. Dahiya

Designation A.R.H. Divisional Officer.