

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / 44 / 2450

Dated 07/10/11

FIRE SAFETY CERTIFICATE

Certified that the Metro Guest house at 639, Churiwalan, Delhi-06 comprised of, Ground + 03 upper floors was granted NOC by this department vide letter No F 6 / DFS / MS / 2008 / 2770 dated 01.10.2008. The premises was re-inspected by the officer concerned of this department on 27.09.2011 in the presence of Owner Mr. Hafis Akram Zamal and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from ..07/10/11... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..07/10/11..... at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station, Defence Colony, New Delhi.
2. The Owner, Metro Guest House, 639, Churiwalan, Delhi-06

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

old ans

3	Compartmentation. <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NR	
4	Smoke Management System. <ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NR	
5	Fire Extinguishers <ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 Nos. w. CO2 4 Nos. CO2 4.5kg ISI marked	10 Nos. w. CO2 - 6 Nos CO2 4.5kg. 4 Nos YES	M/R /
6	First-Aid Hose Reels. <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	II & III floor. 30 m 5 mm	2 Nos YES YES	M/R M/R M/R
7	Automatic fire detection and alarming system. <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/R	
8	MOEFA	N/A	N/R	N/A
9	Public Address System.		Provided.	M/R
10	Automatic Sprinkler System. <ul style="list-style-type: none"> • Basement 	N/A	N/R	N/A

Olden

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		N/A	
11	Internal Hydrants		N/A	
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.		N/A	
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	1	
			N/A	
		225 Lts/minut	225 Lts/min	MIR
		10m	10m	MIR
		-	-	-
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	MIR		MIR

old cost

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		old cost	2500kg	M.F.
15	Exit Signage.	stair/corridor	provided	MIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	
17	Standby power supply		N/A	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:			NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the De Facto Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

1
1
21

Signature of the Inspecting Officer

Name

Designation

Shyam Lal
28/9/2011

Signature of the Inspecting Officer

Name (SHYAM LAL)

Designation Assitt. Divn. Officer