

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/2011/2406

Dated: 04/10/11

**FIRE SAFETY CERTIFICATE**

Certified that the Salwan Public School at Mayur Vihar, Phase -III, Delhi-96, comprised of ground plus three upper floors was granted NOC by this department vide letter no.F.6/DFS/MS/2005/478 dtd.04.03.2005. The premises was re-inspection by the officer concerned of this department on 12.09.11 in the presence of Sh.L.N.Kher(Director) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011 and that the building is fit for occupancy class B "Educational Building" with effect from 04/10/11..... for a period of three years, subject to conditions printed overleaf.

Issued on.....04/10/11.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

To,  
Principal  
Salwan Public School  
Mayur Vihar, Phase -III,  
Delhi-96,

Copy to:-  
The Director Education,  
Government of N.C.T Delhi

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the schedule of Delhi Fire Service Rule 2010. The form is available at [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

002020

N/3

**INSPECTION REPORT**

1. Name & address of the building : Salwan Public School at Mayur Vihar, Phase -III, Delhi-96,
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : Letter No- F.6/DFS/MS/2005/478 Dated 04.03.2005
5. Fire Safety direction letter No : F.16/Estate/ccFire Sefety/2011/3298 to 3398 dated 01.03.11
6. Date of Inspection : 12.09.2011
7. Name of the Inspecting Officers: DO Virendra Singh
8. Name of the designation of Officer  
From the building side : Sh.L.N.Kher(Director)
9. Year of Construction : 2001
- 10.Applicant's letter No : SPS/MV/11/4020 dated 08.08.2011

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 M	15 Mtrs ✓	MR
	• Gate width	4.5M	4.5 Mtrs ✓	MR
	• Width of internal road	5 M	5 Mtrs ✓	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 No	2 NO. ✓	MR
	• Basement	—	—	—
	B. Width of Staircases			
	• Upper Floor	M/R	1.5 Mtrs ✓	MR
	• Basement	—	—	—
	c. Protection of exits			
	• Fire check door	Not	Not required ✓	—
	• Pressurization	—	Not required	—
	e. No. of continuous staircases to terrace	One	2 no. ✓	MR
	g. Width of Corridor	1.5	2 Mtrs ✓	MR
	h. Door Size	1000mm	1.0Mtrs ✓	MR
3	Compartmentation.			
	• Fire check door	—	Not required	—
	• Sealing of electrical shafts	Required	Provided ✓	MR -
	• Fire rating of shaft door	—	Provided	—
	• Water curtain	—	Not required	—
	• Fire Dampers	—	Not required	—
4	Smoke Management System.			
	• Basement	30a/c per hour	Not required	—
	• Upper floor	12 a/c per hour	Not required	—
5.	Fire Extinguisher			
	• Total numbers	20	20 No.	MR ✓
	• types	ABC & CO <sub>2</sub> Type	ABC, CO <sub>2</sub> & water Type	MR ✓
	• IS marking	ISI marked	ISI marked	MR ✓



N/Y

6	First-aid-Hose Reels.			
	• Total numbers of each floor	2 No.	2 No.	MR ✓
	• Length of hose reel hose	30 m	Provided	MR ✓
	• Nozzle diameter	5 mm	Provided	MR ✓
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	Not required	—
	• Location of main panel	—	Ground	→
	• Location of repeater panel	—		
	• Alternate source of power	/	Provided	/
	• Hooters's location			
8	MOEFA	Required	Provided	MR ✓
9	Public address System.	Required	Provided	MR ✓
10	Automatic Sprinkler System.	N/A	Not required	/
	• basement	/	Not required	/
	• upper floor	/	Not required	/
	• sprinkler above false ceiling	/	Not required	/
11	Internal Hydrants	Not Required but provided.		
	• size of riser/down-comer	—	100 mm φ	MR ✓
	• Number of hydrants per floor	—	2 No.	MR ✓
	• Hose Box	—	Provided	MR ✓
12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.	MIR		
	• Ground Level	Not Required	Provided	—
	➢ Discharge of main Pump	/	/	/
	➢ Head of Main Pump	/	/	/
	➢ Number of main pumps	/	/	/
	➢ Jockey pump out put	/	/	/
	➢ Jockey pump head	/	/	/
	➢ Standby pump out put	/	/	/
	➢ Standby pump Head	/	/	/
	➢ Auto Starting /Manual stopping	—	Auto	—
	➢ Pump House Access	—	Provided	MR ✓
	• Terrace Level	Required	Provided	MR ✓
	➢ Discharge of pump	450 LPM	450 lpm	MR ✓
	➢ Head of the Pump	40 Mts	40 Mtrs	MR ✓
	➢ Power supply	—	—	—
	➢ Auto Starting of pump	—	Auto	—
14	Captive Water Storage for Fire Fighting.	MTR		
	• Underground tank capacity	—	60,000 Ltrs ✓	MR ✓
	➢ Draw-off connection	—	Provided	—
	➢ Fire service inlet	—	Provided	—
	➢ Access to tank	—	Provided	—

NIS

	• Overhead Tank capacity	10000 ltrs	10,000 ltrs	MR
15	Exit Signage.	<del>Required</del>	Provided	MR ✓
16	Provision of Lifts.	N/A		
	• Pressurization of Lift Shaft	/	/	/
	• Pressurization of Lift lobby	/	/	/
	• Communication in lift car	/	/	/
	• Firemen's grounding switch	/	/	/
	• Lift Signage	/	/	/
17	Standby power supply	←	Provided	-
18	Refuge Area.	N/A		
	• Total area		/	
	• Location		/	
19	Fire Control Room	N/A		
	• Detector system panel		/	
	• Flow switch panel		/	
	• PA system panel		/	
	• Batter backup		/	
	• Building Floor Plans		/	
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were tested checked and found functional at the of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010/-issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*Virendra Singh*  
 Name **VIRENDRA SINGH**  
 Designation **DO**