

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2011/2418

Date 04/10/11

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya South Anarkali Delhi-51. Comprised of ground plus one upper floor owned/occupied by M/S Nigam Pratibha Vidyalaya South Anarkali Delhi-51, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 12.09.2011 in the presence of Mrs. Asha Gupta Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 04/10/11 for a period of three years, subject to conditions printed overleaf.

Issued on 04/10/11.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

To,

Principal
Nigam Pratibha Vidyalaya
South Anarkali Delhi-51.

Copy to:-

The Director of Education,
MCD, Nigam Bhawan, Kashmiri Gate,
Delhi.

INSPECTION REPORT

1. Name & address of the building : Nagar Nigam Prathamik vidyalaya
2. Type of Occupancy : Educational South Amerikeli ward 231
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : F.16/Estate/LCC/Fire Safety/2011/3298
6. Date of inspection : 12.9.2011 3378 dated 1.3.2011
7. Name of the Inspecting Officers : Suresh Singh ADO
8. Name and designation of officers from the building side : Mrs Asha Gupta Principal
9. Year of Construction : 2005
10. Applicant's letter No. : Nil dated 6.8.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	Access to building	MIR		MR/NMR
	• Road width	—	6. M ✓	—
	• Gate width	—	3.10 M ✓	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits	MIR		
	a. Number of staircases	—	2 ✓	—
	• Upper Floors	—	2 ✓	—
	• Basements	—	—	—
	b. Width of staircases	1.5 M	1.5 M ✓	—
	• Upper Floors	—	1.5 M	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	1.5	2.60 ✓	—
	h. Door Size	1 M	1 M ✓	—

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	—	—	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	—	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 No ISI marked	4 No 3 ABC + 1 CO ₂ 1.5/	✓ ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NIR 30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NIR	— — — — —	— — — — —
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NIR	Provided	
		—	—	

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	-	-	
11	Internal Hydrants	- NIR		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	-	-	
		-	-	
		-	-	
12	Yard Hydrants.	NIR		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	-	-	
		-	-	
13	Pumping Arrangements.	NIR		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
		-	-	
14	Captive Water Storage for fire fighting.	-		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	-	-	
		-	-	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	
15	Exit Signage.	—	—	
16	Provision of Lifts.	— N/A	—	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	— N/A	—	
17	Standby power supply	—	—	
18	Refuge Area.	— N/A	—	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	
19	Fire Control Room	—	—	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	
		N/A	—	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Singh

Signature of the Inspecting Officer

Signature of the Inspecting Office

Name Suresh Singh

Name

Designation ADO

Designation