

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
 NEW DELHI- 110 001

No. F6/DFS/MS/School/2011/2424

Date 04/10/11

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School, Vivek Vihar, Delhi-95. Comprised of ground plus one upper floor owned/occupied by from Govt. Girls Sr. Sec. School, Vivek Vihar, Delhi-95, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 14.09.2011 in the presence of Mrs. Urmila Mittal Vice Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 04/10/11 for a period of three years, subject to conditions printed overleaf.

Issued on 04/10/11 at New Delhi by



Chief Fire Officer
 Delhi Fire Service

To,

Principal
 Govt. Girls Sr. Sec. School,
 Vivek Vihar, Delhi-95
 Copy to:-
 The Joint Director of Education
 (Land & Estate)
 Directorate of Education,
 Lucknow Road, Delhi -54.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt Girl Senior Sec School Virek Vihar
2. Type of Occupancy : Educational Delhi - 95
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : E-16 / Estate / CC / Fire Safety / 2011 / 3298 + 3398
6. Date of inspection : 14.9.2011 dated 1.3.2010
7. Name of the Inspecting Officers : ADO Suresh Singh
8. Name and designation of officers from the building side : Mrs Urmila Mittal vice Principal
9. Year of Construction : 1979
10. Applicant's letter No. : GG SSS / vv / 2011 / 694 dated 27.7.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building	Required		
	• Road width	—	2.0 M	
	• Gate width	—	3.75 M	
	• Width of internal road	—	—	
2	Number, Width, Type & Arrangement of Exits	MIR		
	a. Number of staircases	2	3	
	• Upper Floors	2	2	
	• Basements	—	—	
	b. Width of staircases	1.5 M	1.40 M 1.50 M	
	• Upper Floors	—	1.40 M 1.50 M	
	• Basements	—	—	
	c. Protection of exits	—	—	
	• Fire check door	—	—	
	• Pressurization	—	—	
	e. No. of continuous staircases to terrace	—	No	
	g. Width of Corridor	1.5	2.10	
	h. Door Size	1 M	1 M	

3	Compartmentation.	MIR	Provided	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	—	—	
		—	—	
		—	—	
		—	—	
4	Smoke Management System.	N/A		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	—	
		12 a/c per hour	—	
5	Fire Extinguishers	MIR		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	34 10 CO2 4.5, 24 ABC 151	
6	First-Aid Hose Reels.	N/A		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	— 30 m 5 mm	— — —	
7	Automatic fire detection and alarming system.	N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— — — — —	— — — — —	
8	MOEFA	—	—	
9	Public Address System.	—	Provided	
10	Automatic Sprinkler System.	—	—	
	<ul style="list-style-type: none"> • Basement 	—	—	

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	
11	Internal Hydrants	N/A		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	
12	Yard Hydrants.	N/A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	
13	Pumping Arrangements.	N/A		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	
14	Captive Water Storage for fire fighting.	N/A		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	
15	Exit Signage.	N/A	—	
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	
17	Standby power supply	N/A	—	
18	Refuge Area.	N/A	—	
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	—	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Slugh

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Sunesh Singh

Name

Designation ADO

Designation