

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/2011/ 2482

Dated: 10/10/11

**FIRE SAFETY CERTIFICATE**

Certified that the **Mater Dei School located at Tilak Lane, New Delhi comprised of ground floor and three upper floors** was granted NOC by this department vide letter No. F.6/DFS/MS/95/1601 dated 31-10-1995 . The premises was re-inspected by the officer concerned of this department on 29-09-2011 in the presence of Sister Irene (Principal) and Mr. I.M.Stanly (A.O) of the school and found that the said school have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Educational (School building)** with effect from ~~10/10/11~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~10/10/11~~ at New Delhi by.

  
Chief Fire Officer  
Delhi fire service

Copy to: -

1. The Director of Education, Govt .of NCT of Delhi, Old secretariat, Delhi
2. The Principal, Mater Dei School, Tilak Lane, New Delhi.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Old Case

**INSPECTION REPORT**

1. Name & address of the building : Mater Dei School, Tilak Lane, New Delhi
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/95/1601 Dated: 31-10-1995
5. Fire Safety directives letter No : F.6/DFS/MS/BP/92/1250 Dated 06-07-1992
6. Date of inspection : 29-09-2011
7. Name of the Inspecting Officers : ADO, M.K.Chattopadhyay
8. Name and designation of officers  
from the building side : Sister Irene (Principal) and Shri I.M.Stanly (A.O)
9. Year of Construction : 02-02-1995
10. Applicant's letter No. : Letter No. Nil Dated 22-07-2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width		24 mts	MR
	• Gate width		4.70 mts	MR
	• Width of internal road		5.10 mts	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	-----	-----	-----
	b. Width of staircases			
	• Upper Floors			
	• Basements	1.2 mts as per DFS directives	1.37 mts, 1.20 mts, 1.45 mts, 1.43 mts	MR
	c. Protection of exits			
	• Fire check door			
	• Pressurization	Not required as per DFS Directives	Not required as per DFS Directives	—
	e. No. of continuous staircases to terrace		02	—
	g. Width of Corridor		02.40 mt	MR
	h. Door Size		open staircase	—

Old car

3	<b>Compartmentation.</b>	Not required as per DFS Directives		
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4	<b>Smoke Management System.</b>	No basement - Not applicable		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	----- -----	----- -----
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	35 Nos  ISI marked	13 - ABC type 15 - CO2 type 07 - ABC (2 Kg)	MR MR MR
6	<b>First-Aid Hose Reels.</b>	01 hose reel is required as DFS directives		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	----- 30 m 5 mm	01 at 3 <sup>rd</sup> floor 30 mts 5 mm	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>	Not required		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8	<b>MOEFA</b>	Not required as per	DFS Directives	
9	<b>Public Address System.</b>	Provided in entire	building	
10	<b>Automatic Sprinkler System.</b>	Not required as <sup>per</sup> DFS Directives		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>	Not required as <sup>per</sup> DFS Directives		

add (er)

	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>	<b>Not required as per DFS Directives</b>		
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➢ Discharge of main Pump</li> <li>➢ Head of Main pump</li> <li>➢ Number of main pumps</li> <li>➢ Jockey Pump out put</li> <li>➢ Jockey pump head</li> <li>➢ Standby Pump out put</li> <li>➢ Standby Pump Head</li> <li>➢ Auto Starting/ Manual stopping</li> <li>➢ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➢ Discharge of pump</li> <li>➢ Head of the pump</li> <li>➢ Power Supply</li> <li>➢ Auto Starting of pump</li> </ul> </li> </ul>			
			provided	
			450 LPM	MR
			40 mts	MR
			-----	-----
			Manually started	—
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➢ Draw-off connection</li> <li>➢ Fire service inlet</li> <li>➢ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	50,000 lts	50,000 lts	MR
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		25,00 lts	10,000 lts	MR
15	<b>Exit Signage.</b>	Not required as per	DFS directives	but provided
16	<b>Provision of Lifts.</b>	<b>Not applicable</b>		

old case

	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>	Not required as per	DFS directives	
18	<b>Refuge Area.</b>	<b>Not applicable</b>		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	<b>Fire Control Room</b>	<b>Not required as per DFS directives</b>		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:		02 CO2 type fire extinguishers of 4.5 Kg capacity provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

 30/5/2011  
Signature of the Inspecting Officer

Name

Name M.K. CHATTO PADHYAY