

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / GH / 2400

Dated 3/10/11

FIRE SAFETY CERTIFICATE

Certified that the Guest house Sheiba Lodge, at 5114, Ballimaran, Delhi - 06 comprised of, Ground + 03 upper floor was granted NOC by this department vide letter No F 6 / DFS / MS / 2008 / 2861 dated 13.10.2008. The premises was re-inspected by the officer concerned of this department on 23.09.2011 in the presence of Prop. Mohd. Ibrahim and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" with effect from ...3/10/11... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...3/10/11... at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Comm. of Police (Lic) First Floor, Police Station, Defence Colony, New Delhi.
2. The Manager, Sheiba Lodge Guest house, at 5114, Ballimaran, Delhi - 06

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Building covered under Special Area.
 L. No. F-6/MS/DFS/2001/1795 dt. 29-8-2001

INSPECTION REPORT

1. Name & address of the building: Sheiba Lodge, 5114, Ballimaran, Delhi
2. Type of Occupancy: Group A + Residential.
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No F-6/MS/DFS/GH/08/2861 Dated: 13-10-2008
5. Fire Safety directives letter No: F-6/MS/DFS/GH/2000/1999 dt. 2nd 11/2000 & F-6/MS/DFS/GH/2001/1218 dt. 25.6/01/2001
6. Date of inspection: 23-9-2011.
7. Name of the Inspecting Officers: ADO - SHYAM LAL.
8. Name and designation of officers from the building side: Prop. - Mohd. Ibrahim.
9. Year of Construction: 1979 (Gr+3) 14 Rooms at 1st & 2nd fl.
10. Applicant's letter No: F-6/MS/DFS/GH/08/2861 dt. 13-10-2008.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars G.O. H. /MSL Requirement	Provided at site	Remarks MR/NM
1	Access to building			
	• Road width	L	5 mtrs.	MIR
	• Gate width	N/A	-	
	• Width of internal road	N/A	-	
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	one	one	MR
	• Upper Floors	one	one	MR
	• Basements	N/A	NIL	N/A
	b. Width of staircases	1.25	86 cms.	old car spread
	• Upper Floors		86 cms.	
	• Basements		NIL	
	c. Protection of exits			
	• Fire check door		N/A	
	• Pressurization			
	e. No. of continuous staircases to terrace	one	one	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A		
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A		
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	6 WT & Co2 type yes	MP MR MR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	one 11nd floor provided. provided	MR addces	
7	Automatic fire detection and alarming system.		N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA		N/A		
9	Public Address System.		N/A		
10	Automatic Sprinkler System.		N/A -		
	<ul style="list-style-type: none"> • Basement 				

old case
Special area

3

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants	N/A		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.	N/A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A		
			22.5 lts/unit	m L
			40 m	old case
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	N/A		

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2500	2500 LTS.	m.e.d.l.c.s.
15	Exit Signage.		Provided.	
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.~~ X

Signature of the Inspecting Officer

Shyam Lal
24/9/2011
Signature of the Inspecting Officer

Name

Name *SHYAM LAL*

Designation

Designation *Assitt. Divn. Officer.*