

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2011/ 2533

Dated: 14/10/11

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Sec. School** located at **Chhatarpur, New Delhi-110074** comprised of **Ground + 1 Upper Floor** owned / occupied by **GNCT** The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on **06/09/11** in the presence of **Principal** and that the building / premises is fit for occupancy class **Group 'B' Education Building Sub Division B- I Schools upto Sr. Sec. Level** with effect from **05/10/11** for a period of **Three** years subject to condition as mentioned below.

Issued on 14/10/11 at New Delhi by.



Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Principal, Govt. Girls Sr. Sec. School,
Chhatarpur, New Delhi-110074.

(2) Director of Education,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt Girls Sr. Sec. School, Chhattaipur, NO
2. Type of Occupancy : School upto Sr. Sec. level Education bldg G-B-I⁷⁴
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No : NO
6. Date of inspection : 6/9/11
7. Name of the Inspecting Officers : S. S. Kauslik
8. Name and designation of officers from the building side : Kiran Highwan Principal
9. Year of Construction : 1982
10. Applicant's letter No. : 349 dt. 20/7/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>approachable</u>	<u>Provided</u>	<u>MR</u>
	• Gate width	<u>approachable</u>	<u>Provide</u>	<u>MR</u>
	• Width of internal road	<u>NR</u>	<u>NR ✓</u>	<u>NR</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>2 in each block</u>	<u>4 Nos</u>	<u>MR</u>
	• Basements	<u>N.B.</u>	<u>No Basement</u>	<u>MR</u>
	b. Width of staircases			
	• Upper Floors	<u>150 cms</u>	<u>130 cms x 2</u>	
	• Basements	<u>150 cms</u>	<u>125 cms x 2</u>	
	c. Protection of exits			
	• Fire check door	<u>No Basement</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>Not require</u>	<u>NP</u>	<u>NP</u>
		<u>door</u>	<u>NP</u>	
	e. No. of continuous staircases to terrace	<u>—</u>	<u>None</u>	
	g. Width of Corridor	<u>150 cms</u>	<u>Provided</u>	<u>MR</u>
	h. Door Size	<u>1 mtr</u>	<u>Provided</u>	<u>MR</u>

3	Compartmentation.			MR
	• Fire check door	NR	NP	MR
	• Sealing of electrical shafts	NR	NP	MR
	• Fire Rating of shaft door	NR	NP	MR
	• Water Curtain	NR	NP	MR
	• Fire Dampers	NR	NP	MR
4	Smoke Management System.			
	• Basements	30 a/c per hour	NR	NP
	• Upper floors	12 a/c per hour	NR	NP
5	Fire Extinguishers			
	• Total numbers		26 No.	MR
	• Types		Water or CO ₂ Type	MR
	• IS marking	ISI marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor		NR	—
	• Length of hose reel hose	30 m	NR	—
	• Nozzle diameter	5 mm	NR	—
7	Automatic fire detection and alarming system.			
	• Type of detectors	NR	NR	MR
	• Location of Main Panel	NR	NR	MR
	• Location of Repeater Panel	NR	NP	MR
	• Alternate source of power	NR	NP	MR
	• Hooters' Location	NR	NP	MR
8	MOEFA	Not provided	Not provided	MR
9	Public Address System.	Provided	Provided	MR
10	Automatic Sprinkler System.	Not provided	Not provided	MR
	• Basement	Not required	NP	MR

2

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	MR	ND	MR
		MR	ND	MR
		MR	ND	MR
15	Exit Signage.	Review	ND	MR
16	Provision of Lifts.			MR
	• Pressurization of Lift Shaft	MR	ND	MR
	• Pressurization of Lift lobby	MR	ND	MR
	• Communication In lift Car	MR	ND	MR
	• Fireman's Grounding Switch	MR	ND	MR
	• Lift Signage	MR	ND	MR
17	Standby power supply	MR	ND	MR
18	Refuge Area.	open ground		
	➤ Total Area	MR	ND	MR
	➤ Location	MR	ND	MR
19	Fire Control Room			MR
	• Detector System Panel	MR	ND	MR
	• Flow Switch Panel	MR	ND	MR
	• PA System Panel	MR	ND	MR
	• Batter backup	MR	ND	MR
	• Building Floor Plans	MR	ND	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	MR	ND	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

DFA is put up please

Signature of the Inspecting Officer

Mausht
Signature of the Inspecting Officer

Name

Name

Designation

Designation Asst Div Officer