

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.G./D.F.S./MS/School/2011/2557

Dated: 14/10/11

FIRE SAFETY CERTIFICATE

Certified that the Sarvodya Kanya Vidyalaya –No-1 Gandhi Nagar, Delhi-110031 Comprised of ground plus one upper floor owned/occupied by M/s Sarvodya Kanya Vidyalaya –No-1 Gandhi Nagar, Delhi-110031 have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officers concerned of Fire Service on 09.09.2011 in the presence of Mrs Alka Bansal, Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 14/10/11 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010, printed overleaf.

Issued on.....14/10/11.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

7.10.11

To,
Principal
Sarvodya Kanya Vidyalaya –No-1
Gandhi Nagar, Delhi-110031

Copy to-
The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya 110-1 Gand Nagar
2. Type of Occupancy : Educational - School.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : F16/Estate/CC/ Fire Safety/2011/3298 to 3398
6. Date of inspection : 9.9.2011 dated 1.3.11.
7. Name of the Inspecting Officers : ADP Surash Singh
8. Name and designation of officers from the building side : Principal - Mrs Anka Bansal
9. Year of Construction : 1960
10. Applicant's letter No. : MH S.K.V. No. 1/CC No. 8591 - dt 9.9.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width		15M	MR
	• Gate width	4.50 --	3.15	MR
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		2 4 N	
	• Upper Floors	1.50 M	1.70, 1.50 1.60	MR
	• Basements	---		
	b. Width of staircases			
	• Upper Floors	1.50 M	1.70, 1.50 1.60	MR
	• Basements			
	c. Protection of exits			
	• Fire check door	---	---	
	• Pressurization	---	---	
	e. No. of continuous staircases to terrace	---	---	
	g. Width of Corridor	1.50 M	2 M	MR
	h. Door Size	1 M	2.1 x 1 M	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NA
4	Smoke Management System.			NA
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	20 CO2 10 DCP (ABC) 10	M/L M/L M/L
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NA
8	MOEFA			NA
9	Public Address System.			NA
10	Automatic Sprinkler System.			NA
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none">• Upper Floor• Sprinkler above false ceiling			
11	Internal Hydrants	NA		
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box			
12	Yard Hydrants.	NA		
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box			
13	Pumping Arrangements.	NA		
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.	NA		
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection			

Signature of the Inspecting Officer

SSyl

Name Suresh Singh

Designation ADO

Signature of the Inspecting Officer

~~SSyl~~

Wmo

Name Suresh Singh

Designation ADO