

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2011/2550

Dated: 14/10/11

FIRE SAFETY CERTIFICATE

Certified that the Govt.Sarvodaya Kanya Vidyalaya at Krishna Nagar, Delhi-51. Comprised of ground plus one upper floor owned/occupied by M/s Govt.Sarvodaya Kanya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 21.09.2011 in the presence of Smt. Sushila Panwar, Principal, of the school and that the building is fit for occupancy class B' Educational Building' with effect from 14/10/11..... for a period of **three** years, subject to conditions printed overleaf.

Issued on..... 14/10/11..... at New Delhi by



Chief Fire Officer
Delhi Fire Service

DC
7.10.11

To,
Principal
Govt.Sarvodaya Kanya Vidyalaya
Krishna Nagar, Delhi-51

Copy:-

1. The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.
2. Principal
Govt.Sarvodaya Bal Vidyalaya
Krishna Nagar, Delhi-51

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya
 2. Type of Occupancy : Krishna Nagar, Delhi-51.
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. NIL Dated: NIL
 5. Fire Safety directives letter No. F. 16/Estab/CC/Fire Safety/2011/3298/3298
 6. Date of inspection : 21.09.11 dt. 1.3.2011.
 7. Name of the Inspecting Officers : Do Visendra Singh
 8. Name and designation of officers from the building side : Smt. Sushila Panwar (Principal)
 9. Year of Construction : 1954
 10. Applicant's letter No. : GSKV/KN/11 dt 18/4/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 M	12 M ✓	MR
	• Gate width	4.8 M	5 M ✓	MR
	• Width of internal road	—	NA	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	— 3 No	4	MR
	• Upper Floors	3 No.	4 No. ✓	MR
	• Basements	—	NA	—
	b. Width of staircases			
	• Upper Floors	1.5	1.5 M	MR
	• Basements	/	NA	/
	c. Protection of exits			
	• Fire check door	Not required	NA	/
	• Pressurization	-// -	NA	/
	e. No. of continuous staircases to terrace	Required		
	g. Width of Corridor	1.5	2 M ✓	MR
	h. Door Size	1.0 M	2 X 1 M ✓	MR

3	Compartmentation.	MR	Provided	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NA N NA NA NA	/
4	Smoke Management System.	N/A		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA NA	/
5	Fire Extinguishers	MR		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20 No ISI marked	22 18 ABC 440 ² 151	MR MR MR
6	First-Aid Hose Reels.	N/A		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	NA NA NA	/
7	Automatic fire detection and alarming system.	N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		NA NA NA NA NA	/
8	MOEFA	NA	NA	
9	Public Address System.	NA	Provided	/
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> • Basement 		NA	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		Not required	
			-11-	
			-11-	
15	Exit Signage.		Not required	
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		Not required	
			-11-	
			-11-	
			-11-	
			-11-	
17	Standby power supply		Not required	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		Not required	
			-11-	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		Not required	
			-11-	
			-11-	
			-11-	
			not required	
20	Special Fire Protection Systems for Protection of special Risks, if any:		Not required	

The fire protection systems provided in the building were tested and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.~~

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name VIRENDRA SINGH

Designation DD