

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/EH/2011/2558

Dated: 14/10/2011

FIRE SAFETY CERTIFICATE

Certified that the Mc-Donald's Family Restaurant with 164 seats located at Ground floor, Vishal Cinema Complex, Rajouri Garden, New Delhi-110021 was granted NOC by this department vide letter No F-6/DFS/MS/EH/2008/2343 dated 18/08/2008. The premises was re-inspected by the officers concerned of this department on 27/08/2011 in the presence of Sh Brijesh Tiwari and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 27/08/2011 for a period of three years subject to conditions printed below

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation equipments.
3. The fire suppression protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. The Additional Commissioner of Police (I/c), 1st floor, Police Station, Defense Colony, New Delhi for information
2. M/s Mc-Donald's Family Restaurant, Vishal Cinema Complex, Rajouri Garden, New Delhi

