

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI-110 001

No. F6/DPS/ms/2011/1841

Dated: 04/08/2011

FIRE SAFETY CERTIFICATE

Certified that the **D.A.V. Public School** comprised of ground and three upper floors only at Pushpanjali Enclave, Pitampura, Delhi-110034 have complied with the fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act-2007 and rules 2010 and verified by the officer concerned of Fire Service on 07.07.2011 in the presence of Mrs. Sneha Verma (Principal), D.A.V. Public School and that the building/premises is fit for occupancy Class **B (Educational)** with effect from 04/08/2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/08/2011 at New Delhi by.


DIRECTOR
Delhi Fire Service

To:

The Principal,
D.A.V. Public School,
Pushpanjali Enclave, Pitampura,
Delhi-110034.

Copy to :-

✓ The Director of Education,
Old Secretariat,
Delhi.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
2. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building Bye-Laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first shedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in.