

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/D&S/MS/School/2011/2638

Dated: 21/10/11

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec School at School Block Shakar Pur, Delhi-92. Comprised of ground plus one upper floor owned/occupied by Govt. Girls Sr. Sec School have complied with the fire prevention and fire safety requirements in accordance with with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 23.09.2011 in the presence of Smt. Amardayal Kaur, Principal, of the school and that the building is fit for occupancy class B' Educational Building' with effect from 21/10/11..... for a period of three years, subject to conditions printed overleaf.

Issued on 21/10/11 at New Delhi by



Chief Fire Officer
Delhi Fire Service

QC
Kul
20.10.11

To,
Principal
Govt. Girls Sr. Sec School
School Block Shakar Pur, Delhi-92

Copy:-

1. The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.
2. Principal
Govt. Boys Sr. Sec School
School Block Shakar Pur, Delhi-92

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Gout Girls Sr. Sec School, Shakarpur
2. Type of Occupancy : Educational, School Block, Shakar Pur, Delhi
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: NIL
5. Fire Safety directives letter No : F.16/Estate/As/EC/2011/3298 to 3398 dt/15/11
6. Date of inspection : 23/09/11
7. Name of the Inspecting Officers : Do Vikendra Singh
8. Name and designation of officers from the building side : _____
9. Year of Construction : 1999
10. Applicant's letter No. : NIL, dated 20/9/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 M	20. M	MR
	• Gate width	4.5	5 M	MR
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2 No.	2 No. ✓	MR
	• Upper Floors	2 No	2 No ✓	- II
	• Basements	—	—	—
	b. Width of staircases			
	• Upper Floors	1.5 M	1.5 M ✓	MR
	• Basements	—	Not required	—
	c. Protection of exits			
	• Fire check door	—	Not required	—
	• Pressurization	—	Not required	—
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	2 M	2 M	MR
	h. Door Size	1.0 M	1.0 M	MR

3	Compartmentation.			
	• Fire check door	—	Not required	—
	• Sealing of electrical shafts	—	- // -	—
	• Fire Rating of shaft door	—	- //	—
	• Water Curtain	—	- //	—
	• Fire Dampers	—	- //	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	Not required	—
	• Upper floors	12 a/c per hour	Not required	—
5	Fire Extinguishers			
	• Total numbers	20 no	20 no	MR
	• Types		ABC & CO2	MR
	• IS marking	ISI marked	ISI	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	—	Not required	—
	• Length of hose reel hose	30 m	- // -	—
	• Nozzle diameter	5 mm	- //	—
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	Not required	—
	• Location of Main Panel	—	- // -	—
	• Location of Repeater Panel	—	- // -	—
	• Alternate source of power	—	- //	—
	• Hooters' Location	—	- //	—
8	MOEFA	—	Not required	—
9	Public Address System.	—	- // -	—
10	Automatic Sprinkler System.			
	• Basement	—	Not required	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	Not required	—
		—	- // -	—
		—	- //	—
15	Exit Signage.	—	- // -	—
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	Not required	—
		—	//	—
		—	//	—
		—	- //	—
		—	- //	—
17	Standby power supply	—	- // -	—
18	Refuge Area.	—		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	Not required	—
		—	- // -	—
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	Not required	—
		—	- // -	—
		—	- //	—
		—	- //	—
		—	- //	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	- // -	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/ issue shortcomings as noted at serial numbers ^{safety} ^{delivered}

(Signature)

Signature of the Inspecting Officer

Name: VIRENDRA SINGH

Designation: DO (East)

Signature of the Inspecting Officer

Name

Designation