

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. FG/OFS/ms/school/2011/2638

Dated : 21/10/11

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed Sec.School at GH Block, Old Seema Puri, Delhi-95. Comprised of ground plus one upper floor owned/occupied by Govt. Co-Ed Sec.School have complied with the fire prevention and fire safety requirements in accordance with with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 19.09.2011 in the presence of Sh.R.S.Singh, Principal, of the school and that the building is fit for occupancy class B' Educational Building' with effect from 21/10/11 for a period of three years, subject to conditions printed overleaf.

Issued on.....21/10/11.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

gc
20.10.11

To,
Principal
Govt. Co-Ed Sec.School
GH Block, Old Seema Puri, Delhi-95

Copy:-
The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Co - Ed Sec. School, GH Block
2. Type of Occupancy : Educational old scemabin
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NK Dated: N/C
5. Fire Safety directives letter No : A-16/Estete/CC/FS/2011/3298 to 3398 dt 11/3/11
6. Date of inspection : 18/09/11
7. Name of the Inspecting Officers : DO Visendra Singh
8. Name and designation of officers from the building side : Mr. R-S. Singh (Principal)
9. Year of Construction : 2010
10. Applicant's letter No. : G.co-ed/ss/gh/osp/2011/185 dt 19/7/11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 M	6 M ✓	MR
	• Gate width	4.5 M	5 M ✓	MR
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2 NO.	3 NO. ✓	MR
	• Upper Floors	2 NO.	3 NO. ✓	MR
	• Basements	—	NA	—
	b. Width of staircases	1.5 M	1.5 M ✓	MR
	• Upper Floors	1.5 M	1.5 M ✓	MR
	• Basements	—	NA	—
	c. Protection of exits	—	NA	—
	• Fire check door	—	NA	—
	• Pressurization	—	NA	—
	e. No. of continuous staircases to terrace	—	Not Equipped	—
	g. Width of Corridor	1.5 M	1.5 M ✓	MR
	h. Door Size	1.0 M	1.0 M ✓	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	—	NA	—
		—	NA	—
		—	NA	—
		—	NA	—
		—	NA	—
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA NA	— —
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	9 No - ISI marked	9 No ✓ ABC & CO2 ISI Marked	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Not required 30 m 5 mm	Not required - 11 - - 11 -	— — +
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	—	NA NA NA NA NA	— — — — —
8	MOEFA	—	Not required	—
9	Public Address System.		Not required	—
10	Automatic Sprinkler System.		— NA —	
	<ul style="list-style-type: none"> • Basement 	—	NA	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	Not required	—
		—	- II -	—
		—	- II -	—
15	Exit Signage.	—	- II -	—
16	Provision of Lifts.	—	Not required	—
	• Pressurization of Lift Shaft	—	Not required	—
	• Pressurization of Lift lobby	—	NA	—
	• Communication In lift Car	—	NA	—
	• Fireman's Grounding Switch	—	NA	—
	• Lift Signage	—	NA	—
17	Standby power supply	—	Not required	—
18	Refuge Area.			
	➤ Total Area	—	Not required	—
	➤ Location	—	- II -	—
19	Fire Control Room			
	• Detector System Panel	—	Not required	—
	• Flow Switch Panel	—	- II -	—
	• PA System Panel	—	- II -	—
	• Batter backup	—	- II -	—
	• Building Floor Plans	—	II	- II -
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	Not required	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the ~~Inspecting~~ Officer

Name VIRENDRA SINGH

Designation DO

Signature of the Inspecting Officer

Name

Designation