

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No: F 6/DFS/MS/2011/2727

Dated: 28/10/11

FIRE SAFETY CERTIFICATE

Certified that the "369 Banquet and Lounge" located at 33/33A, Rama Road, New Delhi-110015 comprised of basement, ground floor and two upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by Sh. Sunil Chaudhary Divisional Officer of this department on 19-10-11 in the presence of Shri Sumit Ajwani were present at the time of inspection and that the building/premises is fit for occupancy **Class D (Assembly-Banquet)** with effect from ~~28/10/11~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.



Chief Fire Officer
For Director
Delhi Fire Service

Copy to:

1. The Deputy Health Officer, MCD, Health Department, Rajouri Garden, New Delhi.
2. The Manager, 369 Banquet and Lounge, 33/33 A, Rama Road, New Delhi-110015.

Conditions for the validity of Fire Safety Certificate

- a. All the means of escape shall be kept free of all type of obstruction all the time.
- b. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- c. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- d. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- e. Basement shall be used as per BBI..
- f. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- g. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

May kindly peruse letter no. nil dated 07.07.11 & reminder sent directly to under signed on 15/09/11 with request to issue NOC in favor of Banquet Hall & Lounge named 369^u located at 33/33A Rama Road , New Delhi-110015 this case was dealt earlier by ADO Rajmal Khokhar & DO Than Singh Sharma as per the guidelines issued by M.S. cell now Banquet Hall was re-inspected by undersigned as per the NBC part IV.

1. Name & address of the building : Banquet Hall & Lounge named 369^u located at 33/33A Rama Road ,
New Delhi-110015
2. Type of Occupancy : Class-D (Assembly).
3. Type of Case : New
4. Details of previous NOC : Letter no. F6/DFS/MS/GH/10/1235 dated 28/4/10
5. Fire Safety directives letter No. : N/A
6. Date of inspection : ~~28/06/2011~~ 19-10-2011
7. Name of the Inspecting Officers : DO Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Prem Chawla
9. Year of Construction : NIL
10. Applicant's letter No. : Nil Dated 30/06/2011

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC IV/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 mtrs	60 feets	M.R.
	• Gate width	5 mtrs	5 mtrs	M.R.
	• Width of internal road	Abutting 18 mtr road	N/A	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	two	M.R.

	<ul style="list-style-type: none"> Basement 	Two	three	M.R.
b.	Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	1.5 mtr & 1.25 mtr ,	provided	M.R.
	<ul style="list-style-type: none"> Basement 	1.25 mtr, 1.25 mtr & 1.5 mtr	provided	M.R.
c.	Protection of exits	Fire Check door	provided	M.R.
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Pressurization 	N.R.	N.R.	M.R.
d.	No. of continuous staircases to terrace	two	Provided	M.R.
e.	Width of Corridor	Halls only	Halls only	M.R.
f.	Door size	Two doors each 2 mtr wide	Provided	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N.A.	N.A.	M.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N.A.	N.A.	M.R.
	<ul style="list-style-type: none"> Water Curtain 	N.A.	N.A.	M.R.
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Exhausts fans	Provided	provided
	<ul style="list-style-type: none"> Upper floors 	Exhausts fans	Provided	Provided
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	20	Provided	Provided
	<ul style="list-style-type: none"> Types 	A.B.C. & CO ₂ type	Provided	-

	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	provided
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	Provided
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	provided
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	-do-
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Heat & smoke type	Provided	M.R.
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	N/R	" "
	<ul style="list-style-type: none"> Location of Repeater Panel 	Ground floor	N/R	" "
	<ul style="list-style-type: none"> Alternate source of power 	required	Provided D.G. Set 65 KVA	" "
	<ul style="list-style-type: none"> Hooter's Location 	N.R	Provided	" "
8.	MOEFA	N/R	provided	" "
9.	Public Address System.	N/R	provided	" "
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	required	Provided	M.R.
	<ul style="list-style-type: none"> Upper Floor 	N.R	Provided	" "
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	" "
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	4 inch	4 inch	" "
	<ul style="list-style-type: none"> Number of hydrants per floor 	one	Provided	" "

	• Hose Box	one	Provided	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	one	Provided	M.R.
	• Hose Box	one	Provided	" "
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	M.R.
	➤ Head of Main pump	" "	" "	" "
	➤ Number of main pumps	" "	" "	" "
	➤ Jockey Pump out put	(O.H) 180 LPM	180 LPM	" "
	➤ Jockey pump head	(O.H.) 45 mtr	Provided	" "
	➤ Standby pump out put	(O.H) 2280 LPM	Provided	" "
	➤ Standby pump Head	(O.H) 45 mtr	Provided	" "
	➤ Auto Starting/Manual stopping	" "	" "	" "
	➤ Pump Hose Access	" "	" "	" "
	Terrace level			
	➤ Discharge of pump	2 x 2280	Provided	M.R.
	➤ Head of the pump	45 mtr	" "	" "
	➤ Power supply	required	" "	" "
	➤ Auto Starting of pump	" "	" "	" "
14.	Captive Water Storage for fire fighting.			

	Underground tank capacity	N.R. <i>same capacity had been provided</i>	N.P. <i>N</i>	M.R.
	➤ Draw-off connection	N.R.	" "	" "
	➤ Fire service inlet	N.R.	" "	" "
	➤ Access to tank	N.A	" "	" "
	➤ Overhead Tank Capacity	50,000	50,000 ltrs	" "
15	Exit Signage.	N.R.	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A. <i>Not provided</i>	N.A. <i>Not provided</i>	M.R.
	• Pressurization of Lift lobby	" "	" "	" "
	• Communication In lift Car	" "	" "	" "
	• Fireman's Grounding Switch	" "	" "	" "
	• Lift Signage	" "	" "	" "
17.	Standby power supply	N.R.	D.G. set 100 K.V.A	" "
18.	Refuge Area	N.R.		
	➤ Total Area	N.R.	N.R.	M.R.
	➤ Location	N.R.	N.R.	" "
19.	Fire Control Room	N.R.	N.R.	" "
	➤ Detector System Panel	N.R.	N.R.	" "
	➤ Flow Switch Panel	N.R.	N.R.	" "
	➤ PA system Panel	N.R.	N.R.	" "
	➤ Batter backup	N.R.	N.R.	" "

	➤ Building Floor plans	N.R.	N.R.	M.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	" "

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer

Signature of the Inspection Officer

Name *Sunil Chandra*

Name

Designation *D-O/MN*

Designation