

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI-110 001

No. FG/DFS/MS/2011/EN/2723

Dated: 27/10/2011

FIRE SAFETY CERTIFICATE

Certified that Chirag Foods located at 226, Moments Mall, 67 Patel Road, Kirti Nagar, New Delhi-15 have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 10.10.2011 in the presence of authorized signatory of restaurant & that the premises is fit for occupancy Class D (Assembly) with effect from 27/10/11 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/10/2011 at New Delhi by.



DIRECTOR  
Delhi Fire Service

To:

Authorised Signatory,  
Chirag Foods,  
226, Moments Mall,  
67 Patel Road, Kirti Nagar,  
New Delhi-15.

etc

Following fire safety directives must be adhered to: -

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
4. Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building Bye-Laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May kindly peruse the letter no. nil dated 22.09.2011 received from Authorised Signatory regarding issuance of NOC from fire safety point of view in favour of restaurant in the name & style of Chirag Foods located at 226, Moments Mall, 67 Patel Road, Kirti Nagar, New Delhi-15.

The point wise compliance of fire safety recommendations with the Delhi Fire Service Act-2007 & rules 2010 are given below:-

INSPECTION REPORT				
1	Name & Address of the building	Chirag Foods 226, Moments Mall, Kirti Nagar		
	Type of occupancy	Assembly (Restaurant)		
3	Type of case	New Case		
4	Details of previous NOC	Nil		
5	Fire Safety directives letter no.	Nil		
6	Date of Inspection	10.10.2011		
7	Name of the Inspecting officers	Do (MN) Sunil Chowdhary		
8	Name and designation of officers from the building			
9	Year of Construction	20/10/2011		
10	Applicant's letter no.	Nil dated 22.09.2011		
S.N	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	12 mtr.	30 mtr.	MR
	Gate width	6 mtr.	12 mtr.	MR
	Width of internal road	6 mtr.	6 mtr.	MR
2	Number, Width, type & Arrangement of Exits			
	a. Number of staircases	14	14	MR
	Upper Floors	14	14	MR
	Basement	14	14	MR
	a. Width of staircases	2 mtr. & 1.5 mtr.	2 mtr. & 1.5 mtr.	MR
	Upper Floors			
	Basements	2 mtr. & 1.5 mtr.	2 mtr. & 1.5 mtr.	MR
	b. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	Required	Provided	MR
	c. No. of continuous staircases to terrace	14	14	MR
	d. Width of Corridor	8 mtr.	8.2 mtr.	MR
	e. Door Size	2 mtr.	2 mtr.	MR
3	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	2 hr.	Provided	MR
	• Water curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper Floors	12 a/c per hour	Provided	MR

5	<b>Fire Extinguishers</b>	30 ISI marked	Provided in mall	MR
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>		ABC type	MR
			Yes	MR
6	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	16	15 nos.	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 mtrs.	Yes	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Yes	MR
7	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main panel</li> </ul>	Ground Floor	"/"	
	<ul style="list-style-type: none"> <li>Location of repeater Panel</li> </ul>	Ground Floor	"/"	
	<ul style="list-style-type: none"> <li>Alternation source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooper's location</li> </ul>	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11	<b>Internal Hydrants</b>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Size of riser down-comer</li> </ul>	150 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	16	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	16	Provided	MR
12	<b>Yard Hydrants</b>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	10	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	10	Provided in the mall	MR
13	<b>Pumping Arrangements</b>	As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>	As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	2280 LPM, As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Head of Main pump</li> </ul>	75 mtrs., As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	3, As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Jockey pump output</li> </ul>	180 LPM, As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Jockey Pump Head</li> </ul>	75 mtrs., As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Standby Pump output</li> </ul>	2280 LPM, As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Standby pump head</li> </ul>	75 mtrs., As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Auto starting/Manual stopping</li> </ul>	Auto, As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	Required, As per Mall	Provided	MR
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>	NR	NP	MR
	<ul style="list-style-type: none"> <li>Discharge of the pump</li> </ul>	NR	NP	MR
	<ul style="list-style-type: none"> <li>Head of the Pump</li> </ul>	NR	NP	MR
	<ul style="list-style-type: none"> <li>Power Supply</li> </ul>	NR	NP	MR
	<ul style="list-style-type: none"> <li>Auto Starting of Pump</li> </ul>	NR	NP	MR
14	<b>Captive Water Storage for fire fighting</b>	As per capacity of mall		
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	2 lakh, As per capacity of mall	Provided	MR
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	Required, As per capacity of mall	Provided	MR
	<ul style="list-style-type: none"> <li>Fire Service inlet</li> </ul>	Required, As per capacity of mall	Provided	MR
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	Required, As per capacity of mall	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	50,000, As per capacity of mall	Provided	MR

16	<b>Provision of Lifts</b>	Required	Provided	MR
	• Pressurization of Lift Shaft	As per mall ✓	Provided ✓	MR
	• Pressurization of Lift Lobby	As per mall ✓	Provided ✓	MR
	• Communication in lift car	As per mall ✓	Provided ✓	MR
	• Fireman's Grounding Switch	As per mall ✓	Provided ✓	MR
	• Lift Signage	As per mall ✓	Provided ✓	MR
17	<b>Standby Power Supply</b>	Required	Provided ✓	MR
18	<b>Refuge Area</b>	NR	NP	NA
	• Total Area	-	-	-
	• Location	-	-	-
19	<b>Fire Control Room</b>	Required	Provided	MR
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA system Panel	-	-	-
	• Battery backup	-	-	-
	• Building Floor Plans	-	-	-
20	<b>Special Fire Protection Systems for Protection of Special Risks, if any:</b>	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



Signature of the Inspecting officer

Signature of the Inspecting officer

Name Sunil Chaudhary

Name

Designation D.O. (G/D)

Designation