

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FD/DF3/MS/ET/2011/2897

Dated: 08/11/2011

FIRE SAFETY CERTIFICATE

Certified that the Game of a Legend-Goal (A Unit of M/s Apple International), located at TF-02A, Third floor, City Square Mall, Raja Garden, New Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 06.10.11 in presence of Sh. Manoj Sharoror (Manager) of restaurant and that the premises is fit for Class D (Assembly) occupancy with effect from08/11/2011.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....08/11/2011.....at New Delhi by



Chief Fire Officer
Delhi Fire Service



Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor,
Police Station, Defense Colony, New Delhi for information
2. Sh. Manoj Sharoror (Manager)
Game of a Legend-Goal (A Unit of M/s Apple International),
TF-02A, Third floor, City Square Mall, Raja Garden, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 22-09-2011 received from Authorized signatory Game of a Legend-Goal (A Unit of M/s Apple International) regarding issue of NOC in favor of their restaurant located at TF-02A, Third floor, City Square Mall, Raja Garden, New Delhi. This Mall has already been issue NOC wide letter no. F6/DFS/MS/2005/2314 dated 08/11/2005 and number of NOC are issued to restaurant located at the same floor i.e. 3rd floor ~~no.~~ width of the staircase, corridors etc have already been taken ^{NOC} use of during the last NOC's. However following fire safety points are put up on the prescribe Performa

1. Name & address of the building : "Game of a Legend-Goal" (A Unit of M/s Apple International) located at TF-02A, Third floor, City Square Mall, Raja Garden, New Delhi.
2. Type of Occupancy : Cass D (Assembly)
3. Type of Case : New Case
4. Details of previous NOC : F6/DFS/MS/2005/2314 dated 08/11/2005 (For Mall)
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 06.10.2011
7. Name of the Inspecting Officers : Division Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Sh. Manoj Sharoror (Manager)
9. Year of Construction :
10. Applicant's letter No. : nil dated 22-09-2011

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtrs	30 mtr ✓	M/R
	• Gate width	5 mtr	5 mtr ✓	M/R
	• Width of internal road	6 mtr	6 mtr ✓	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			

	<ul style="list-style-type: none"> Upper Floors 	Three	Three	In Mall/M.R
	<ul style="list-style-type: none"> Basement 	Five	Five	** / M.R
b.	Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	Required	Provided	Specification has already being earlier inspection checked.
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R
c.	Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R
	<ul style="list-style-type: none"> Pressurization 	Required	Provided	M.R
d.	No. of continuous staircases to terrace	three	three	M.R
e.	Width of Corridor	Required	Provided	M.R
f.	Door size	2 mtrs.	2 mtr	Width of the restaurant Gate M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	In Mall/ M.R
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	sealed	** / M.R
	<ul style="list-style-type: none"> Fire Rating of shaft door 	4 hrs	Provided	** / M.R
	<ul style="list-style-type: none"> Water Curtain 	N.R.	N.R.	** / M.R
	<ul style="list-style-type: none"> Fire Dampers 	N.R.	N.R.	** / M.R
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided	In Mall / M.R
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	** / M.R

3.	Fire Extinguishers			
	• Total numbers	20	provided ✓	" / M.R
	• Types	ABC & CO ₂	provided ✓	" / M.R
	• IS marking	required	provided ✓	" / M.R
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	two	two ✓	In Mall/M.R
	• Length of hose reel hose	30 m	30 mtr ✓	" / M.R
	• Nozzle diameter	5 mm	5 mm ✓	" / M.R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Head	Provided ✓	In Mall/M.R
	• Location of Main Panel	Ground floor	Provided ✓	" / M.R
	• Location of Repeater Panel	Ground floor	Provided ✓	" / M.R
	• Alternate source of power	Required	2 generator 450 KVA each ✓	" / M.R
	• Hooter's Location	Required	Provided ✓	" / M.R
8.	MOEFA	Required	Provided ✓	" / M.R
9.	Public Address System.	Required	Provided ✓	" / M.R
10.	Automatic Sprinkler system			
	• Basement	Required	Provided ✓	" / M.R
	• Upper Floor	Required	Provided ✓	" / M.R
	• Sprinkler above false ceiling	Required	Provided ✓	" / M.R
11.	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	150 mm	** / M.R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2	2	** / M.R. ✓
	<ul style="list-style-type: none"> • Hose Box 	2	2	** / M.R ✓
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	4	Provided	** / M.R ✓
	<ul style="list-style-type: none"> • Hose Box 	required	Provided	** / M.R ✓
13.	Pumping Arrangements.			
	Ground Level	Required	Provided	It has already been checked during earlier inspection In Mall /M.R ✓
	➤ Discharge of main pump	2850 LPM ✓	Provided
	➤ Head of Main pump	80 mtr ✓	Provided
	➤ Number of main pumps	2 ✓	Provided
	➤ Jockey Pump out put	180 LPM ✓	Provided
	➤ Jockey pump head	80 mtr ✓	Provided
	➤ Standby pump out put			
	➤ Standby pump Head	2850 LPM ✓	Provided
	➤ Auto Starting/Manual stopping	80 mtr ✓	Provided
	➤ Pump Hose Access	Required	Provided
	Terrace level	Required	Provided
	➤ Discharge of pump	900 LPM ✓	Provided

	➤ Head of the pump	80 mtr	Provided
	➤ Power supply	Required	Provided	** / M.R
	➤ Auto Starting of pump	Required	Provided	** / M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	100,000	100,000	** / M.R
	➤ Draw -off connection	Required	Provided	** / M.R
	➤ Fire service inlet	Required	Provided	** / M.R
	➤ Access to tank	Required	Provided	** / M.R
	➤ Overhead Tank Capacity	Required	Provided	** / M.R
15	Exit Signage.	(30,000 ltr) Required	Provided	In Mall & Restaurant
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	In Mall / M.R
	• Pressurization of Lift lobby
	• Communication In lift Car
	• Fireman's Grounding Switch
	• Lift Signage
17.	Standby power supply	Required	Provided	In Mall/ M.R
18.	Refuge Area	N.R.	N.R	In Mall/ M.R
	➤ Total Area
	➤ Location

19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided ✓	In Mall/ M.R
	➤ Flow Switch Panel	Required	Provided ✓	" "
	➤ PA system Panel	Required	Provided ✓	" "
	➤ Batter backup	Required	Provided ✓	" "
	➤ Building Floor plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name *Sumit Chaudhary*

Name

Designation *D.O. (West)*

Designation