

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F 6 / DFS / MS / 2011 / EN / 2982

Dated 15/11/2011

FIRE SAFETY CERTIFICATE

Certified that the Havemore Restaurant, at 11-12, Pandara Road Mkt., New Delhi comprised of, Ground + first floor was granted NOC by this department vide letter No F5 / (12) / DFS / 96 / 416 dated 23.12.1996. The premises was re-inspected by the officer concerned of this department on 08.11.2011 in the presence of Mr. Parvesh Bajaj and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building Group D of Sub Division-D5 with effect from 15/11/2011 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/11/2011 at New Delhi by


DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Medical Officer of Health, Health Department, Palika Kendra, NDMC, New Delhi-01
2. Havemore Restaurant, at 11-12, Pandara Road Mkt., New Delhi

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

- 1 Name & address of the building : HAVEMORE Restaurant, 11-12, Ponnakal.
- 2 Type of Occupancy : Restaurant
- 3 Type of Case : New Case/ Renewal ✓
- 4 Details of previous NOC : Letter No FS/12/DFS/96/416 Dated: 23/12/96
- 5 Fire Safety directives letter No : N/A
- 6 Date of inspection : 5/8/11 & 8/10/11
- 7 Name of the Inspecting Officers : ATULGAEG & S.J. KANUR
- 8 Name and designation of officers from the building side : DO & ADO
Mr P. Pravej
- 9 Year of Construction : Before -1993 AS per records
- 10 Applicant's letter No. : 13/07/11

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>main rd</u>	<u>main Rd</u>	<u>MR</u>
	• Gate width	<u>N/A</u>	<u>N/A</u>	<u>MR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>MR</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>N/A</u>	<u>N/A</u>	<u>—</u>
	• Upper Floors	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>N/A/ MR</u>
	b. Width of staircases	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	• Upper Floors	<u>—</u>	<u>—</u>	<u>—</u>
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>N/A</u>	<u>N/A</u>	<u>MR</u>
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>N/A MR</u>
	• Pressurization	<u>N/A</u>	<u>NA</u>	<u>N/A</u>
	e. No. of continuous staircases to terrace	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	g. Width of Corridor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	h. Door Size	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

old con

3	Compartmentation.			
	• Fire check door	N/A	N/A	MR
	• Sealing of electrical shafts	N/A	N/A	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers		7	MR
	• Types		CO ₂ & DCP	MR
	• IS marking	ISI marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor		N/A	old gas mr
	• Length of hose reel hose	30 m	N/A	old con
	• Nozzle diameter	5 mm	N/A	old
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	MR
	• Location of Main Panel	N/A	N/A	N/A / mn
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA			
		N/A	N/A	N/A
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A

old copy

(4)

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	
15	Exit Signage.	Yes	Yes	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... N/A.....

Kausht

Signature of the Inspecting Officer

Name S.S. Kausht

Designation Asst Div. Officer

Atul Singh

Signature of the Inspecting Officer

Name ATUL SINGH

Designation DD/CL