

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/GH/2011/2725

Dated : 27/10/2011

FIRE SAFETY CERTIFICATE

Certified that the Lamba Guest House located at C-5,Kalkaji,New Delhi comprised of Basement , Ground + 3 Upper Floor was granted NOC by this department vide letter No.F6/DFS/MS/GH/2008/2737 dated 26/09/08 The premises was re-inspected by the officer concerned of this department on 13/10/11 in the presence of Mr. Lamba and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Lodging or Rooming House** with effect from -- 29/10/2011 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire subject to conditions printed overleaf.

Issued 27/10/2011 at New Delhi by,

Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Addl. Commissioner of Police, (Lic.),
First Floor, PS Defence Colony,
New Delhi
(2) Lamba Guest House, C-5, Kalkaji, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

-H/15-

INSPECTION REPORT

short-comings found ~~notified~~

1. Name & Address of the building: Lamba Guest House c-5, Kalkaji New Delhi
 2. Type of Occupancy : Lodging or Rooming House
 3. Type of Case : New Case Renewal
 4. Details of Previous NOC : Letter No PC/DES/MS/GH/2008 Dated 26/9/08
 5. Fire Safety directives letter No. : N.O.
 6. Date of inspection : 13.10.11
 7. Name of Inspecting Officers : S. S. Kausik Asstt. Div Officer
 8. Name and designation of Officers from the building side : Mr. Lamba
 9. Year of construction : 1993
 10. Applicant's letter No. : No MR At 7.10.11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at Site	Remarks
	Access to building		1.2mtr	MR
	• Road width	9 mtr	10 mtr	MR
	Gate width	MR	MR	MR
	• Width of internal road	—	—	—
	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	One	Two ✓	MR
	• Upper floors	Two	Two ✓	MR
	• Basement			
b.	Width of staircase	125cm	120cm/72cm old care	MR
	• Upper Floors	125cm	do	MR
	• Basements			
c.	Protection of exits	Required	Provided	MR
	• Fire Check door	MR	NP	—
	• Pressurization			
d.	No. of continuous staircases to terrace	Required one	—	MR
e.	Width o' Corridor	Hofgren 1.10cm	—	MR
f.	Door Size	One mtr	One mtr ✓	MR
	Compartmentation.			
	• Fire check Door	Required	Provided	MR
	• Sealing of electrical shafts	MR	110g. of 1	MR

-N/B -

	• Fire rating of shaft door	Regm/nr BF	1 hr frontier	MR & old law
	• Water curtain	NR	-	-
	• Fire Dampers	NR	-	-
Smoke Management System.				
	• Basements	30 a/c per hour	Exhaust fan provided	old case
	• Upper Floors	12 a/c per hour	Exhaust provided	old law
Fire Extinguishers				
	• Total Numbers	10 nos Regm	11 Nos Provided	MR
	• Types		ABC available	MR
	• IS Marking	ISI Marked	yes	
First -Aid Hose Reels.				
	• Total numbers of each floor		one each	MR
	• Length of hose reel hose	30 m	4-5	MR
	• Nozzle diameter	5 mm	yes	MR
Automatic fire detection & alarming system.				
	• Type of detectors	Not required		
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooter's Location			
MOEFA				
		Required	Provided	pn 12
Public Address System.				
		Required	Provided	ME
Automatic Sprinkler System.				
	• Basement	Required nBF	Provided	MR
	• Upper Floor	NR Required	NP	-
	• Sprinkler above false ceiling	NR Required	NP	-
Internal Hydrants				
	• Size of riser down-comer	NR Required	NP	-
	• Number of hydrants per floor	-1-	-1-	-
	• Hose Box	-1-	-1-	-1-
Yard Hydrants.				
	• Total Number of hydrants	NR Required		

13

Pumping Arrangements

• Ground Level	➤ Discharge of main pump						
	➤ Head of Main pump						
	➤ Number of main pumps						
	➤ Jockey Pump out put						
	➤ Jockey pump head						
	➤ Standby pump out put						
	➤ Standby pump head						
	➤ Auto Starting/Manual stopping						
	➤ Pump House Access						
• Terrace level	➤ Discharge of pump	Required	450 LPM	✓	mA	old law	
	➤ Head of the pump	Required	40mtr	✓	mA	old law	
	➤ Power supply	Required	Provided	mA			
	➤ Auto Starting of pump	Required	Yes	mA			

Captive Water Storage for Fire Fighting

• Underground tank capacity	Required	24,000 Ltr	mA	
➤ Draw-off connection	NR	—	—	
➤ Fire service inlet	NR	—	—	
➤ Access to tank	NR	—	—	
• Overhead Tank capacity	5000 Ltr	Provided	mA	

Exit Signage.

Required Provided mA

Provision of Lifts.

No lift No

- Pressurization of Lift Shaft
- Pressurization of Lift Lobby
- Communication In lift Car
- Fireman's Grounding Switch

Not required

-N/18 -

	• Lift Signage	✓	—	—
17.	Standby power supply	D.G Set Provided	M.R	
18.	Refuge Area.			
	➢ Total Area	Not Required		
	➢ Location	/	/	/
19.	Fire Control Room			
	• Detector System Panel	Not required	—	—
	• Flow Switch Panel	—/—		
	• PA System Panel	Required	Provided	M.R
	• Batter backup	Required	Provided	M.R
	• Building Floor Plans			

20. Special Fire Protection Systems for Protection of special Risks, if any.

No spcl fire protection system provided

The fire protection systems provided in the building were test checked and functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire and fire safety required under the rules it is recommended to grant Fire Safety under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings a. numbers.....

Accordingly draft copy is put up P

Marsly

Signature of Inspecting Officer

Signature of Inspecting Officer

Name

Name S. S. Kausik

Designation

Designation Asstt. Div. Officer