

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


No F 6 DFS MS EH 2011 2989

DATED 16/11/2011

FIRE SAFETY CERTIFICATE

Certified that M/s Pizza Hut Restaurant building at T - 317, Ambience Mall, Vasant Kunj, New Delhi is running at the 3RD Floor comprised of three tier basement, ground plus three upper floors was granted NOC by this department vide letter No F 6 DFS MS 2008 3282 dated 28.11.2008 for Mall. The premises re-inspected by the officer concerned of Fire Service on 13.10.2011 in the presence of Mr Sidharth Kumar (Manager) of the restaurant and that the building is fit for occupancy Class D "Restaurant Building" in the mall with effect from 16/11/2011 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, as mentioned below.

Issued on 16/11/2011 at New Delhi


Chief Fire Officer
For Director
Delhi Fire Service

Copy to:-

1. The DHO (South Zone), Office of Dy Health Officer, MCD, Health Deptt. South Zone, Green Park, New Delhi
2. The Manager, Pizza Hut Restaurant
1 - 317, 3RD Floor, Ambience Mall,
Vasant Kunj, New Delhi

CONDITIONS FOR VALIDITY OF THE FIRE SAFETY CERTIFICATE

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non functional shall be the responsibility of the management.
2. Building sanctioning authority may verify and deviation with regard to construction - occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner / occupier shall submit a declaration every year in Form K provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Pizza Huts (A unit of Devyani International Ltd) at T-317, 3rd Floor Ambience Mall, Vasant Kunj New Delhi		
2	Type of Occupancy	Mercantile "F"		
3	Type of case	New for Resturant		
4	Details of previous NOC	F6/MS/DFS/2008/3282 Dated 28.11.2008		
5	Fire safety directives letter No	F6/MS/DFS/BP/2004/3070 Dated 20.12.2004		
6	Date of inspection	13.10.2011		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO(BCP) S.S.Kaushik		
8	Name and designation of officers from the building side	Mr.Sidharth (Manager Pizza Hut), & Mr. Ram Narian (Mall Fire Officer)		
9	Year of construction	2014 2008		
10	Applicant's letter No.	Nil Dt. 16.09.2011		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	18 mtrs	Provided	MR
	2) Gate width	5mtrs	Provided	MR
	3) Width of internal road	6 mtrs	Provided	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases	29 Nos.		
	1. Upper floors	Required	14 Nos Provided by Mall	MR
	2. basements	Required	29 Nos. Provided by Mall	MR
	b. Width of staircase			
	1. Upper floors	1.5 mtrs	Provided by Mall	MR
	2. basements	1.5 mtrs	Provided by Mall	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided by Mall	MR
	d. No. of continuous staircase to terrace	Required	12 Nos. Stairs Provided	MR
	e. Width of corridor	4 mtrs	Provided by Mall	MR
	f. Door size	1.5 mtrs	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided by Mall & Resta	MR
	2. Sealing of electrical shafts	Required	Provided by Mall	MR
	3. Fire Rating of shaft door	Required	Provided by Mall	MR
	4. water curtain	Required	Provided by Mall	MR
	5. Fire dampers	Required	Provided by Mall	MR
4	Smoke Management system.			
	basement	30 a/c per hour	Mechanical Ventilation	
		12 a/c per hour	Provided by Mall	MR
	upper floors		Mechanical Ventilation	
			Provided by Mall	MR
5	Fire Extinguishers			
	total numbers		13 Nos	MR
	Types		ABC, Co2	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	20 Nos.	Provided by Mall	MR
	Length of Hose reel hose	30 m	Provided by Mall	MR
	Nozzle Diameter	5 mm	Provided by Mall	MR

7	Automatic fire detection and alarming system			
	Type of detectors	Required	Provided (Smoke)	MR
	location of Main Panel	Required	Provided (Lower ground	MR
	location of Repeater panel	Required	Provided by Mall	MR
	Alternate source of power	Required	Battary Backup	MR
	hooter's location	Staircase	Provided by Mall	MR
8	MOEFA	Required	Provided by Mall	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided by Mall	MR
	upper floors	Required	Provided by Mall	MR
	sprinkler above false ceiling	Required	Provided by Mall	MR
11	Internal Hydrants			
	Size of riser/down-corner	150 MM	Provided by Mall	MR
	Number of Hydrants per floor	Required	Provided by Mall	MR
	hose Box	Required	Provided by Mall	MR
12	Yard Hydrants.			
	total number of hydrants	Required	Provided by Mall	MR
	hose box	Required	Provided by Mall	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2280 LPM	Provided by Mall	MR
	b.Head of main pump	70 Mtr	Provided by Mall	MR
	c.Number of main pumps	Two	Provided by Mall	MR
	d.jockey pump out put	180 LPM	Provided by Mall	MR
	e.jockey pump head	70 Mtr	Provided by Mall	MR
	f. Standby Pump output	2280 LPM	Provided by Mall	MR
	g.Stanby Pump head	70 Mtr	Provided by Mall	MR
	h.Auto Starting/Manual stopping	Required	Provided (Both)	MR
	pump house access	Required	Provided by Mall	MR
	2.Terrace level			
	a. Discharge of pump	900 LPM	Provided by Mall	MR
	b. head of the pump	40 mtr	Provided by Mall	MR
	c. Power supply	Required	Provided by Mall	MR
	d. Auto starting of pump	Required	Provided by Mall	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	525000 Ltrs	Provided by Mall	MR
	a. Draw-off connection	Required	Provided by Mall	MR
	b. fire service inlet	Required	Provided by Mall	MR
	c.Access to tank	Required	Provided by Mall	MR
	Over head tank Capacity	30,000 ltr	Provided by Mall	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	Required	Provided by Mall	MR
	b. pressurization of lift lobby	Required	Provided by Mall	MR
	c. communication in lift car	Required	Provided by Mall	MR
	d. Fireman's grounding switch	Required	Provided by Mall	MR
	e. Lift signage	Required	Provided by Mall	MR
17	Standby power supply	Required	Provided by Mall & Resta	MR
18	Refuge Area.			
	total area			
	location			

19	Fire control room			
	a. detector system Panel	Required	Provided by Mail	MR
	b. Flow switch Panel	Required	Provided by Mail	MR
	c. PA system Panel	Required	Provided by Mail	MR
	d. Batter backup	Required	Provided by Mail	MR
	e. Building floor plans	Required	Provided by Mail	MR
20	Special Fire Protection systems for protection of special risks, if any:			
<p>The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ May be recommended for the said restaurant subject to conditions give in the letter Accordingly DFA is put up for your approval and signature please.</p>				
Signature of the inspecting officer		Signature of the inspecting Officer		
Name	D. P. Bhardwaj	Name	S.S. Kaushik	
Designation :	Divisional Officer (South)	Designation :	ADO (BCP)	