GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE NEW DELHI-110001.

No. F6/DFS/MS/4H/2011/183/

Dated 04/08/11

FIRE SAFETY CERTIFICATE

Certified that The Indravan Guest House located at 11, Man Singh Road, New Delhi Comprised of Basement Floor, Ground Floor + 2 Upper Floors (Guest House is being run on Ground + 2 Upper Floors only with 24 Rooms) owned / occupied by Sh. Rajpal Singh Kochar have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 27/07/11 in the presence of Mr. Prem and that the building/premises is fit for occupancy class Group A Sub Division A-I Lodging or Rooming Houses with effect from 27/07/11 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on -94/02/11 at New Delhi by

Chief Fire Officer Delhi Fire Service

Copy to :-

- Medical Officer of Health, NDMC, Palika Kendra, Sansad Marg, New Delhi.
- 2. Sh. Rajpal Singh Kochar, The Indravan Guest House,
 - 11. Man Singh Road, New Delhi.

Conditions for the validity of fire safety certificate

- 1. All the means of escape/entry/exit shall be kept free from any obstruction.
- All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
- All the staff members must know the correct method of operation of fire fighting system.
- Any lapse rendering fire fighting system/equipment non- functional shall be the risk and responsibility of the management.
- 5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
- The owner/ occupier shall submit a declaration every year in form "K' provided the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in