

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-1(BA3)/MS/2011/2023

Dated: 20/10/2011

FIRE SAFETY CERTIFICATE

Certified that the Sant Nirankari Public School is comprised of Ground + one upper floor only thus below 09 mtrs, located at Avtar Enclave, Paschim Vihar, New Delhi H0063 have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 13/09/2011 in the presence of Smt Meenakshi Head Mistress, Sant Nirankari Public School and that the building premises is fit for occupancy of Group Class B (Educational) with effect from 20/10/11 to 20/10/14 period of three years, subject to conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be in the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 20/10/11 at New Delhi by

  
Chief Fire Officer  
For Director  
Delhi Fire Service

Copy to:

1. Smt Meenakshi (Head Mistress), Sant Nirankari Public School, Avtar Enclave, Paschim Vihar, New Delhi H0063
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : Sant Nironbari Public School, Astar Enclave, Panchim Vihar, New Delhi-63
2. Type of Occupancy : Assembly / Institution. (G+1 school)
3. Type of Case : ~~New Case~~  Renewal
4. Details of previous NOC : Letter No. F6/DFS/ms/2008-09/350 Dated 25/2/09
5. Fire Safety directives letter No. : NIL
6. Date of inspection : 13/09/2011
7. Name of the Inspecting Officers : SS Tuli (ADO)
8. Name and designation of officers from the building side : Headmistress Mrs Meenakshi
9. Year of Construction : Before 1995
10. Applicant's letter No. : SNPS/AE/2011/423 dttd 26/7/2011

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks M/R/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	4.5 M	4.5 M	M/R
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	3	3	—
	• Type: Doors	1.5	113, 132 & 137 cms	Being old case M/R.
	• Basements	—	—	—

b. Width of staircases			
• Upper Floors	1.5	113, 132 & 138 cm	MR
• Basements	—	—	—
c. Protection of exits	N/R	NP	MR
• Fire check door	N/R	NP	MR
• Pressurization	N/R	NP	MR
e. No. of continuous staircases to terrace	3	Provided	MR
g. Width of Corridor	Reqd.	Provided.	MR
h. Door Size	1 mtr.	Provided 2 doors in each class room.	MR
3. Compartmentation.	N/R	N/P	MR/NA
• Fire check door	—	—	—
• Sealing of electrical shafts	—	—	—
• Fire Rating of shaft door	—	—	—
• Water Curtain	—	—	—
• Fire Dampers	—	—	—

4	Smoke Management System.		N/R		
	• Basements	30 a/c per hour	-	-	
	• Upper floors	12 a/c per hour	-	-	
5	Fire Extinguishers				
	• Total numbers		08 NOJ	m/r	
	• Types	ISI marked	ABC TYPE	m/r	
	• IS marking		Provided	m/r	
6	First-Aid Hose Reels.				
	• Total numbers on each floor		one at each floor	m/r	
	• Length of hose reel hose	30 m	Provided	m/r	
	• Nozzle diameter	5 mm	Provided.	m/r	
7	Automatic fire detection and alarming system.				
	• Type of detectors	N/R	N/P	N/A	
	• Location of Main Panel	- " -	- " -	- " -	
	• Location of Repeater Panel	- " -	- " -	- " -	
	• Alternate source of power	- " -	- " -	- " -	
	• Hooters' Location	- " -	- " -	- " -	
8	MOEFA	N/R	NP	N/A	
9	Public Address System.	N/R	NP	N/A	

10 Automatic Sprinkler System.

• Basement	NR	NP	N/A
• Upper Floor	NR	NP	N/A
• Sprinkler above false ceiling	N/R	NP	N/A

11 Internal Hydrants

• Size of riser down-comer	N/R	NP	N/A
• Number of hydrants per floor	N/R	NP	N/A
• Hose Box	N/R	NP	N/A

12 Yard Hydrants.

• Total number of hydrants	NR	NP	N/A
• Hose Box	N/R	NP	N/A

13 Pumping Arrangements.

• Ground Level	N/A	N/A	N/A
➤ Discharge of main Pump	-	-	-
➤ Head of Main pump	-	-	-
➤ Number of main pumps	-	-	-
➤ Jockey Pump out pit	N/A	N/A	N/A
➤ Jockey pump head	N/A	N/A	N/A
➤ Standby Pump out pit	N/A	N/A	N/A
➤ Standby Pump Head	N/A	N/A	N/A

➤ Auto Starting & Manual stopping	NR	NP	N/A
➤ Pump House Access	N/R	NP	N/A
Terrace level	Reqd	Provided	m/R
➤ Discharge of pump	450 LPM	- " -	- " -
➤ Head of the pump	40 m	- " -	- " -
➤ Power Supply	-	-	-
➤ Auto Starting of pump	-	-	-

#### 14 Captive Water Storage for fire fighting.

• Underground tank capacity	N/R	NP	N/A
➤ Draw-off connection	- " -	- " -	- " -
➤ Fire service inlet	Reqd.	Provided	m/R
➤ Access to tank	Reqd	Provided	m/R
• Overhead Tank capacity	5000 ltr	Provided	m/R



15	Exit Signage.	Req'd	Provided	M/R
16	Provision of Lifts.	N/R	NP	N/A
	• Pressurization of Lift Shaft	-	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In Lift Car	-	-	-
	• Fireman's Grounding Switch	-	-	-
	• Lift Signage	-	-	-
17	Standby power supply	Req'd.	15 KVA.	M/R
18	Refuge Area.	N/R	NP	N/A
	• Total Area	-	-	-
	• Location	-	-	-
19	Fire Control Room	N/R	NP	N/A
	• Detector System Panel	-	-	-
	• Flow Switch Panel	-	-	-
	• PA System Panel	-	-	-
	• Battery backup	-	-	-
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special risks, if any?	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 ~~issue shortcomings as noted at serial numbers~~.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

*Gupta*

Name

Designation

*ADD (MN)*

Designation