

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110 001

No. F8 (DFS) Ms/2011/2672

Dated: 24/10/11

FIRE SAFETY CERTIFICATE

Certified that the **Arya Vidya Mandir (Recognised)** is comprised of ground & two upper floors only thus below 09 meters located at Arya Samaj Lane, Keshav Puram, Lawrence Road, Delhi-35 have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education & verified by the officer concerned of Fire Service on 07.09.2011 in the presence of Sh. Manvir Singh Rana (Manager), Arya Vidya Mandir (Recognised) and that the building/premises is fit for occupancy Class B (Educational) with effect from 24/10/11 for a period of three years subject to the conditioned mentioned below.

Issued on 24/10/11 at New Delhi by



DIRECTOR

Delhi Fire Service

To:

Sah. Manvir Singh Rana (Manager),
Arya Vidya Mandir (Recognised)
Arya Samaj Lane, Keshav Puram,
Lawrence Road, Delhi-35

07/10/11
21/10

Copy to: -

The Director of Education,
Old Secretariat,
Delhi.

May kindly see the letter no.AVM/518/11 dated 13.07.2011 received from Mr. Manvir Singh Rana (Manager), Arya Vidya Mandir (Recognised) at Arya Samaj Lane, Keshav Puram, Lawrence Road, Delhi-110035 regarding issuance of NOC from fire safety point of view. Premises was inspected by the ADO (WP) on 07.09.2011 & observed that the school building is comprised of ground & two upper floors only having plot area approx 500 sq. mtrs. and covered area is 350 sq. mtrs. approx.

The point wise compliance of fire safety recommendations accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education are given below:-

INSPECTION REPORT				
1	Name & Address of the building	Arya Vidya Mandir (Recognised)		
	Type of occupancy	Arya Samaj Lane, Keshav Puram, Lawrence Road, Delhi-35		
	Type of case	Educational		
3	Type of case	New Case (Old Building)		
4	Details of previous NOC	Nil		
5	Fire Safety directives letter no.	Nil		
6	Date of Inspection	07.09.2011		
7	Name of the Inspecting officers	Mr. Raj Mal Khokhar, ADO(WP)		
8	Name and designation of officers from the building	Mr. Manvir Singh Rana (Manager)		
9	Year of Construction	Year 1975 (Old Building)		
10	Applicant's letter no.	AVM/518/11 dated 13.07.2011		
S.N	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	8 mtrs.	MR
	Gate width	5 mtrs.	5 mtrs.	MR
	Width of internal road	NR	NP	
2	Number, Width, type & Arrangement of Exits			
	a. Number of staircases			
	Upper Floors	2 nos. ✓	Provided	MR
	Basement	NA	NA	
	a. Width of staircases			
	Upper Floors	40 inch each ✓	Provided	MR
	Basements	NA	NA	
	b. Protection of exits			
	Fire check door	NR	NP	
	Pressurization	NR	NP	
	c. No. of continuous staircases to terrace	One stair	Provided	MR
	d. Width of Corridor	NR	NP	
	e. Door Size	1 mtr. width & 2 mtrs. in height in each room	Provided	MR
3	Compartmentation			
	• Fire check door	NR	NP	
	• Sealing of electrical shafts	NR	NP	
	• Fire Rating of shaft door	NR	NP	
	• Water curtain	NR	NP	
	• Fire Dampers	NR	NP	
4	Smoke Management System			
	• Basements	NR	NP	
	• Upper Floors	NR	NP	

5	Fire Extinguishers			
	• Total numbers	6 Nos.	Provided	MR
	• Types	ABC type cap. 5 kg.	Provided	MR
	• ISI marking	Yes	Provided	MR
6	First-Aid Hose Reels			
	• Total numbers on each floor	one on each floor	Provided	MR
	• Length of hose reel hose	30 mtrs.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NR	NP	
	• Location of Main panel	NR	NP	
	• Location of repeater Panel	NR	NP	
	• Alternation source of power	NR	NP	
	• Hooter's location	NR	NP	
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	NA	NA	
	• Upper Floor	NR	NP	
	• Sprinkler above false ceiling	NA	NA	
11	Internal Hydrants			
	• Size of riser/down-come	NR	Provided	
	• Number of hydrants per floor	one on each floor	Provided	
	• Hose Box	one on each floor	Provided	
12	Yard Hydrants			
	• Total number of hydrants	NR	NP	
	• Hose Box	NR	NP	
13	Pumping Arrangements			
	• Ground Level	NR	NP	
	• Discharge of main pump	NR	NP	
	• Head of Main pump	NR	NP	
	• Number of main pumps	NR	NP	
	• Jockey pump output	NR	NP	
	• Jockey Pump Head	NR	NP	
	• Standby Pump output	NR	NP	
	• Standby pump head	NR	NP	
	• Auto starting/Manual stopping	NR	NP	
	• Pump House Access	NR	NP	
	• Terrace Level	Required	Provided	MR
	• Discharge of the pump	450 lpm	Provided	MR
	• Head of the Pump	40 mtrs.	Provided	MR
	• Power Supply	NR	NP	
	• Auto Starting of Pump	NR	NP	
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	NR	NP	
	• Draw-off connection	NR	NP	
	• Fire Service Inlet	NR	NP	
	• Access to tank	NR	NP	
	• Overhead Tank capacity	5000 ltrs.	Provided	MR
15	Exit Signage	Required	Provided	MR

16	Provision of Lifts			
	• Pressurization of Lift Shaft	NR	NP	
	• Pressurization of Lift Lobby	NR	NP	
	• Communication in lift car	NR	NP	
	• Fireman's Grounding Switch	NR	NP	
	• Lift Signage	NR	NP	
17	Standby Power Supply	NR	NP	
18	Refuge Area			
	• Total Area	NR	NP	
	• Location	NR	NP	
19	Fire Control Room			
	• Detector System Panel	NR	NP	
	• Flow Switch Panel	NR	NP	
	• PA system Panel	NR	NP	
	• Batter backup	NR	NP	
	• Building Floor Plans	NR	NP	
20	Special Fire Protection Systems for Protection of special Risks, If any:	NA	NA	

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate accordance with the circular No. F.16/Estate/CC/Fire Safety/2011-3298-3398 dated 01.03.2011 issued by Director of Education.



Signature of the Inspecting officer

Name **RAJ MALKHOSHKAR**

Designation **A.D.O.**

DO (M.N)

Dy. C.F.O. ; Speaks H
DO (M.N)

dm
7/10/11

A.D.O. (W.P)

DO (M.N)

dm

Dy. C.F.O.

spoken to Dy. C.F.O. & again submitted P.L.

dm
19.10.11

Signature of the Inspecting officer

Name

Designation

16	Provision of Lifts			
	• Pressurization of Lift Shaft	NR	NP	
	• Pressurization of Lift Lobby	NR	NP	
	• Communication in lift car	NR	NP	
	• Fireman's Grounding Switch	NR	NP	
	• Lift Signage	NR	NP	
17	Standby Power Supply	NR	NP	
18	Refuge Area			
	• Total Area	NR	NP	
	• Location	NR	NP	
19	Fire Control Room			
	• Detector System Panel	NR	NP	
	• Flow Switch Panel	NR	NP	
	• PA system Panel	NR	NP	
	• Batter backup	NR	NP	
	• Building Floor Plans	NR	NP	
20	Special Fire Protection Systems for Protection of special Risks, If any:	NA	NA	

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate accordance with the circular No. F.16/Estate/CC Fire Safety, 2011/3298-3398 dated 01.03.2011 issued by Director of Education.



Signature of the Inspecting officer

Name **RAJ MALKHACHAR**

Designation **A.D.O.**

Signature of the Inspecting officer

Name

Designation