

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/D FS/MS/EH/2011/2888

Dated: 04/11/2011

FIRE SAFETY CERTIFICATE

Certified that the Cavendish Banquet & Restaurant located at D-4, Udyog, Nagar, Near Peera Garhi Chowk, New Delhi-110041, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 06.10.11 in presence of Sh. Pardeep Jain (Manager) of Banquet & Restaurant and that the premises is fit for Class-D (Assembly) occupancy with effect from ...04/11/11.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....04/11/11.....at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service



Copy to:
Sh. Pardeep Jain (Manager)
Cavendish Banquet & Restaurant
D-4, Udyog, Nagar, Near Peera Garhi Chowk,
New Delhi-110041

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 08-08-2011 received from Authorized signatory Cavendish Banquet Hall, requesting to issue NOC from fire safety point of view in favor of Cavendish Banquet & restaurant. Inspection was carried out and observed that building is comprised of basement, ground, first floor, terrace is covered with fiber sheet & is used for kitchen, pumps, cooling tower etc. ground floor is used for banquet & upper floor is for restaurant each floor measuring 1316.49 sq mtr out of which 805.518 sq mtr at ground & 797.419 sq mtr at first floor is used for banquet & restaurant respectively.

1. Name & address of the building : Cavendish Banquet & restaurant located at D-4, Udyog, Nagar, Near Peera Garhi Chowk, New Delhi-110041.
2. Type of Occupancy : Cass D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/96/45, F6/MS/DFS/2007/EN/1318 dated 10-052007
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2011/1338 dated 30-06-11
6. Date of inspection : 06.10.2011
7. Name of the Inspecting Officers : Division Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Sh. Pardeep Jain (Manager)
9. Year of Construction : 1996
10. Applicant's letter No. : nil dated 08-08-2011

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	30 mtr ✓	M.R.
	• Gate width	4.5 mtr	5 mtr ✓	M.R.
	• Width of internal road	15.2"	provided ✓	M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Two	Provided ✓	M.R.
	• Upper Floors	Two	Provided ✓	M.R.

	<ul style="list-style-type: none"> Basement 	Two	Provided	M.R. ✓
b.	Width of staircases	1.5 mtr	Provided ✓	M.R. ✓
	<ul style="list-style-type: none"> Upper Floors 	1.5 mtr	Provided ✓	M.R. ✓
	<ul style="list-style-type: none"> Basement 	1.5 mtr	Provided ✓	M.R. ✓
c.	Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided ✓	M.R. ✓
	<ul style="list-style-type: none"> Pressurization 	N.R.	N.R.	M.R. ✓
d.	No. of continuous staircases to terrace	Two	provided ✓	M.R. ✓
e.	Width of Corridor	N.R./Halls	N.R.	M.R. ✓
f.	Door size	2 mtrs	provided ✓	M.R. ✓
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	<i>Provided</i>	M.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	No. electrical shafts available ✓	M.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	required	No. electrical shafts available ✓	M.R.
	<ul style="list-style-type: none"> Water Curtain 	N.R.	N.R.	M.R.
	<ul style="list-style-type: none"> Fire Dampers 	required	<i>only</i> Split A.C. are provided ✓	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided ✓	M.R.
	<ul style="list-style-type: none"> Upper floors 	Required	Provided ✓	M.R.
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	20	provided ✓	M.R.

	<ul style="list-style-type: none"> Types 	ABC & CO ₂ type	provided	M.R
	<ul style="list-style-type: none"> IS marking 	ISI marks	provided	M.R
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	One on each floor	provided	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat type are required	Provided	M.R
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	M.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	Ground floor	Provided	M.R
	<ul style="list-style-type: none"> Alternate source of power 	Required	provided	M.R
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System.	Required	Provided	M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	provided	M.R
	<ul style="list-style-type: none"> Number of hydrants per floor 	one	provided	M.R

	• Hose Box	required	provided ✓	M.R ✓
12.	Yard Hydrants.			
	• Total number of hydrants	N.R	N.R.	M.R ✓
	• Hose Box	N.R	N.R.	✓ M.R ✓
13.	Pumping Arrangements.			
	Ground Level	N.R	N.R.	M.R
	➤ Discharge of main pump	" "	" "	" "
	➤ Head of Main pump	" "	" "	" "
	➤ Number of main pumps	" "	" "	" "
	➤ Jockey Pump out put	" "	" "	" "
	➤ Jockey pump head	" "	" "	" "
	➤ Standby pump out put	" "	" "	" "
	➤ Standby pump Head	" "	" "	" "
	➤ Auto Starting/Manual stopping	" "	" "	" "
	➤ Pump Hose Access	" "	" "	" "
	Terrace level			
	➤ Discharge of pump	900 LPM ✓	Provided	M.R
	➤ Head of the pump	40 mtr ✓	Provided	" "
	➤ Power supply	Required ✓	Provided	" "
	➤ Auto Starting of pump	Required ✓	Provided	" "

14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	One lack	provided	M.R.
	➤ Draw -off connection	required	" "	" "
	➤ Fire service inlet	" "	" "	" "
	➤ Access to tank	" "	" "	" "
	➤ Overhead Tank Capacity	Required 20,000 ltr	20,000 ltr	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A.	N.A.	M.R
	• Pressurization of Lift lobby	" "	" "	" "
	• Communication In lift Car	" "	" "	" "
	• Fireman's Grounding Switch	" "	" "	" "
	• Lift Signage	" "	" "	" "
17.	Standby power supply	Required	60 K.V.A.	M.R
18.	Refuge Area	N.R.	N.R	M.R
	➤ Total Area	" "	" "	" "
	➤ Location	" "	" "	" "
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	M.R
	➤ Flow Switch Panel	N.R.	N.R.	M.R

		Required	Provided	M.R
	➤ PA system Panel			M.R
	➤ Batter backup	" "	" "	M.R
	➤ Building Floor plans	" "	" "	M.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	M.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chawdhary

Name

Designation

D-O (M/N)

Designation