

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110 001

No. F6/D95/MS/2011/1833

Dated: 04/08/11

FIRE SAFETY CERTIFICATE

Certified that the **PP International School at L.D. Block, Pitam Pura, New Delhi** comprised of basement, ground floor and four upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 27.07.2011 in the presence of Shri Pawan Gupta of PP International School, and that the building/premises is fit for occupancy Class B (School Building) with effect from 04/08/11... for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/08/11..... at New Delhi by



(A.K.SHARMA)
DIRECTOR
Delhi Fire Service

Copy to:

1. The President, PP Charitable Trust (Regd.), 2681, beadon Pura, Gali No. 2, Karol Bagh, New Delhi-110005
2. The Director of Edu., Govt. of NCT of Delhi, Old Sectt., Delhi

CONDITIONS FOR THE VALIDITY OF FIRE SAFETY CERTIFICATE

- a. All the fire safety & means of escape facility shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non functional shall be the responsibility of the management.
- b. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.