

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/School/2011/ 3010

Dated: 16/11/11

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary School** located at **South Ext.-I, New Delhi-110003**. Comprised of **Ground + 1 Upper Floor** owned / occupied by **MCD** The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/ 2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on **15/10/11** in the presence of **Mr. Satish Kumar** and that the building / premises is fit for occupancy class **Group 'B' Education Building Sub Division B- I** with effect from **08/11/11** for a period of Three years subject to condition as mentioned below.

Issued on 16/11/11 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to: - (1) The Principal M.C. Primary School,
South Ext.-I, New Delhi-110003.

(2) Director of Education,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of thr management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.the form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- M.C.Primary School, South Extn. Part-I, New Delhi-110003
2. Type of occupancy:- Education Building Schools Up to Sr.Sec. Level
3. Type of case:- New Case
4. Details of previous NOC:- No
5. Fire safety directives No.- No
6. Date of inspection:- 15/10/11
7. Name of the inspecting officer:- ADO S.S.Kaushik
8. Name & designation of officer
From the building side:- Mr. Satish kumar Principal
9. Year of construction:- 2009
10. Applicant's letter No:- 01 dated 04/08/11 *Ground & upper floor*

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Approachable	Yes	MR
	2) Gate width	<i>Approachable</i>	<i>Yes</i>	<i>MR</i>
	3) Width of internal road			
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases	Two	Two	MR
	1. Upper floors	Two	Two	MR
	2. Basements	No basement		
	B. Width of staircase			
	1. Upper floors	150 cms. <i>Required</i>	153cms.& 125cms. ✓	MR
	2. Basements	<i>No Basement</i>		
	C. Protection of exits			
	1. Fire check door	<i>Not Required</i>		
	2. Pressurization	<i>Not Required</i>		
	D. No. of continuous staircase to terrace	<i>Required</i>	Two	MR
	E. Width of corridor	<i>Required</i>	<i>open</i>	<i>MR</i>
	F. Door size	<i>one meter</i>	<i>Provided</i>	<i>MR</i>
3.	Compartmentation		Not Required	
	1) Fire check door	<i>Not Required</i>		

	2) Sealing of electrical shafts	Not Required	—	—
	3) Fire rating of shaft door	—	—	—
	4) Water curtain	—	—	—
	5) Fire Dampers	—	—	—
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Not Required	—
	2) Upper floors	12 a/c per hour	—	—
5.	Fire Extinguishers			
	1) Total numbers	Required ISI Marked	4 Nos. 5 K.G.	MR
	2) Types		ABC	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel		Not Required	
	1) Total number of each floor		—	—
	2) Length of hose reel hose	30 m	—	—
	3) Nozzle diameter	5 mm	—	—
7.	Automatic Fire Detection & Alarming System		Not Required	
	1) Type of detectors	Not Required	—	—
	2) Location of main panel	—	—	—
	3) Location of repeater panel	—	—	—
	4) Alternate source of power	—	—	—
	5) Hooter's Location	—	—	—
8.	MOEFA		Not Required	
9.	Public Address System	Electric bell provided	provided	MR
10.	Automatic Sprinkler System		Not Required	—
	1) Basement	—	—	—
	2) Upper floors	—	—	—
	3) Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants		Not Required	
	1) Size of riser/down-comer	— MR — MR	—	—
	2) Number of hydrants per floor	—	—	—
	3) Hose box			
12.	Yard Hydrants		Not Required	—

	1) Total number of hydrants	Not Required	-	-
	2) Hose box			

13.	Pumping Arrangement	Not Required	Not Required			
	1) Ground level	-	/	/		
	a) Discharge of main pump	-				
	b) Head of main pump	-				
	c) Number of main pump					
	d) Jockey pump out put					
	e) Jockey pump head					
	f) Stand by pump output					
	g) Stand by pump head					
	h) Auto starting/Manual stopping					
	2) Terrace level					
	a) Discharge of pump					
	b) Head of pump					
	c) Power supply					
	d) Auto starting of pump					
14.	Captive Water Storage for Fire Fighting	Not Required				
	1) Under ground tank capacity	/			/	/
	a) Draw-off connection	/	/	/		
	b) Fire service inlet	/	/	/		
	c) Access to tank	/	/	/		
	d) Over head tank capacity	/	/	/		
15.	Exit Signage.	Required	Yes	MR		
16.	Provision of Lifts.	Not Required	Not Required			
	a) Pressurization of lift shaft	/	/	/		
	b) Pressurization of lift lobby	/	/	/		

	c) Communication in lift car			
	d) Fireman's switch			

	e) Lift signage			
17.	Stand by Power Supply	Not Required		
18.	Refuge Area	Not Required	Open space area	
	Total area location			
19.	Fire Control Room	Not Required		
	a) Detector system panel			
	b) Flow switch panel			
	c) PA system panel			
	d) Battery backup			
	e) Building floor plan			
20.	Special Fire Protection System for Protection of special Risk, if any:			Not Required

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/issue as noted at serial numbers-----

Accordingly DSA is put up Pl.

Signature of the inspecting officer

S. S. Kausluk
24/10/11
Signature of the inspecting officer

Name

Name

Designation

Designation

S. S. Kausluk

Asst. Div. Officer

8