

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No.F6/DFS/MS/School/2011/ 2909

Dated: 08/11/11

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C.D. Primary School** located at **Janta Grih-II, D.D.A. Flats, Kalkaji, New Delhi-110019** Comprised of **Single Storey Building** owned / occupied by **MCD** The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire/Safety/ 2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of Fire Service on 14/10/11 in the presence of **Mr. Ajra Imtiaz** and that the building / premises is fit for occupancy class **Group 'B' Education Building Sub Division B- I** with effect from 26/10/11 for a period of Three years subject to condition as mentioned below.

Issued on 08/11/11 at New Delhi by.

  
Chief Fire Officer  
Delhi Fire Service

- Copy to: - (1) The Principal,  
M.C.D. Primary School, Janta Grih-II,  
D.D.A. Flats, Kalkaji, New Delhi-110019.  
(2) Director of Education,  
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. the form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

-N/1-

## INSPECTION REPORT

1. Name & Address of the building: Nagar Nigam Prathmic Vidyalaya
2. Type of Occupancy : Educational Bldg School up to 5th level
3. Type of Case : New Case/ Renewal
4. Details of Previous NOC : Letter No. NO Dated: 20/07/11
5. Fire Safety directives letter No. : NO
6. Date of inspection : 14.10.11
7. Name of Inspecting Officers : S.S. Kaushik Asstt. Div. Officer
8. Name and designation of Officers from the building side : Ms. Ajra Imtiaz Principal
9. Year of construction : 1973
10. Applicant's letter No. : No N/L 30.6.11 Single Storey

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at Site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Approachable	Yes	M R
	• Gate width			
	• Width of internal road	On Approachable Road		Single Storey
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NO Staircase	Not Required	Not Required
	• Upper floors			
	• Basement	NO Basement		
	b. Width of staircase			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire Check door			
	• Pressurization			
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	-	Open Space	-
	f. Door Size			
3.	<b>Compartmentation.</b>			
	• Fire check Door	not Required	Not Required	-
	• Sealing of electrical shafts	1-	1-	1-

N/2

	<ul style="list-style-type: none"> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	Not Required	/	/
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floors</li> </ul>	30 a/c per hour 12 a/c per hour	Not required	/
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total Numbers</li> <li>• Types</li> <li>• IS Marking</li> </ul>	ISI Marked	4 Nos Stl Cap. End ABC	MR MR
6.	<b>First -Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers of each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	Not required	/
7.	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>	Not required	Not required	/
8.	<b>MOEFA</b>		Not required	/
9.	<b>Public Address System.</b>		Ele. bells provided for alarming	/
10.	<b>Automatic Sprinkler System.</b>		Not required	Not required
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>		/	/
11.	<b>Internal Hydrants</b>		Not required	/
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		/	/
12.	<b>Yard Hydrants.</b>		Not required.	/
	<ul style="list-style-type: none"> <li>• Total Number of hydrants</li> </ul>		/	/

13.	<b>Pumping Arrangements</b> <ul style="list-style-type: none"> <li>• Ground Level           <ul style="list-style-type: none"> <li>➤ Discharge of main pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby pump out put</li> <li>➤ Standby pump head</li> <li>➤ Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level           <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	<i>Not required</i> <i>Not Required</i>			
14.	<b>Captive Water Storage for Fire Fighting</b> <ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	<i>Not required</i>			
15.	<b>Exit Signage.</b>	<i>Not Required</i>			
16.	<b>Provision of Lifts.</b>	<i>Not required</i>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift Lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> </ul>				

1/4

	• Lift Signage	no lift		
17.	Standby power supply			
18.	Refuge Area.	not required open space area		
	➤ Total Area			
	➤ Location	/	/	/
19.	Fire Control Room	not required		
	• Detector System Panel	/	/	/
	• Flow Switch Panel	/	/	/
	• PA System Panel	/	/	/
	• Batter backup	/	/	/
	• Building Floor Plans	/	/	/
20	Special Fire Protection Systems for Protection of special Risks, if any.	not required		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Accordingly DSA is put up R.

Signature of Inspecting Officer

Name

Designation

A

*(Signature)*

Signature of Inspecting Officer

Name S. S. Kaushik.

Designation Asst Dir. Infra