

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : CONNAUGHT LANE
NEW DELHI-110 001.

No. F S / (CBA) / DFS / CNG-Petrol / 2011/237 Dated: 15/11/2011

FIRE SAFETY CERTIFICATE

Certified that the **CNG Dispensing Station**, located at 10/7, Mile Stone, Village Alipur, G.T. Karnal Road, Delhi, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 19.10.2011 in the presence Shri Vitul Ahuja and is fit for occupancy class **Petroleum** with effect from 15/11/2011 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010.

Issued on 15/11/2011 at New Delhi by



Director
Delhi Fire Service

Shri Vitul Ahuja,
M/s. Nem Chand Tara Chand,
10/7, Mile Stone, Village Alipur,
G.T. Karnal Road, Delhi.



Copy to :

Shri Manish Garg, Dy. Manager (Engineering), Delhi Retail Delivery, Bharat Petroleum Corp. Ltd., Bijwasan Institution, Bijwasan, New Delhi-11 0061..

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

May kindly see the letters No. DT/NCTC dated 26.08.2011 received from Shri Manish Garg, Dy. Manager Engineering, Bharat Petroleum Corporation Ltd., Bijwasan Installation, Bijwasan, New Delhi-61, regarding the grant of NOC for existing CNG dispensing in respect of M/s. Nem Chand Tara Chand at 10/7, Mile Stone, Village Alipur, G.T. Karnal Road, Delhi.


In this connection, it is stated that the above said proposed site for CNG filling station has been inspected by Assistant Divisional Officer (Bawana) on 15.10.2011 from fire safety point of view in the presence of Vitul Ahuja and found that the CNG station is constructed as per the site plan submitted by the Bharat Petroleum Corporation Limited and the same may be approved from fire safety of point of view.

During course of inspection it has been observed that the CNG Station alongwith retail petrol pump is existing on a plot area measuring approximately 4800 sq. mtrs. The system components are CNG compressor, radiator, mobile cascade, cylinders, CNG dispensers etc. The owner has provided the following fire safety measures as directed vide this office letter No. F.5(3A)DFS/CNG/2010/03 dated 07.01.2011:

- (1) Exits are provided as per building bye laws clause-16.
- (2) Adequate ventilation is provided as per part-VIII, Section 1 of National Building Code of India.
- (3) The distribution cables/ wiring are laid down through metal circuit and earth leakage circuit breaker is provided and all the equipments of station are earthed properly.
- (4) Miniature Circuits Breakers of appropriate current rating of IS (8828-1978) certification mark are properly installed to eliminate the risk of the fire due to electrical short circuit.
- (5) 10 portable fire extinguishers of ISI marked of ABC and CO2 type are provided.
- (6) The photocopy of license issued by Chief Controller of Explosive is enclosed.
- (7) "No Smoking" sign board both in "Hindi" and "English" has been displayed at different location, which is easily readable by all persons.
- (8) "No" trade susceptible to cause ignition to CNG by generating heat, mechanical/ electric spark has been seen.
- (9) No overhead electric cable at CNG dispensing station has been seen.
- (10) Boundary wall of 6 feet height with fencing is provided.
- (11) The workers at the site are well trained to maintain the record and fire extinguishers.

In view of above, this department has no objection to grant the NOC from fire safety point of view. If agreed, fire certificate is put for signature please.

Divisional Officer (North West)


Assistant Divisional Officer (Bawana)