

No: F6/DF-S/MS/school/2011/2890

Dated: 04/11/11

To

The Vice Principal,
Govt. Boys Secondary School,
IInd shift Naraina,
New Delhi-110028.

Ref No : No.GBSS/IInd/NAR/11/11 dated 23.05.2011.

FIRE SAFETY CERTIFICATE

Certified that the - Govt Boys Secondary School, IInd shift Naraina, New Delhi:- 110028 comprised of - ground floor plus one upper floors, owned/occupied by Govt. of N.C.T. school has complied with the fire prevention and fire safety requirements in accordance with the Director of Education circular No. F.16/Estate/CC/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 18.10.2011 in the presence of - Sh. S.L. Meena Vice. Principal and that the building/premises is fit for occupancy class - group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on04/11/11.....at New Delhi.



Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Director
Govt. of N.C.T. of Delhi
Directorate of Education,
Old Secretariat, Delhi
2. The Principal
Sarvodaya BAL Vidyalaya
Ist shift Naraina,
New Delhi-110028.



INSPECTION REPORT

1. Name & address of the building : Gurt Bays Sec-School, 3rd Sjt Navaina ND.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. N/C Dated:
5. Fire Safety directives letter No : N/C
6. Date of inspection : 18/10/11
7. Name of the Inspecting Officers : D.O. H.C. Anuja
8. Name and designation of officers from the building side : Sh. G. Meena Vice Principal.
9. Year of Construction :
10. Applicant's letter No. : CBSS/2nd/NRH/11/11 dt 23.5.11.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	18mtr	MR.
	• Gate width	R	4.45 mtr	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	3 Nos.	MR
	• Upper Floors	—	—	MR
	• Basements	N/C	N/C	N/C
	b. Width of staircases	R	2 nos 150 ^{cm} each. 1 no 150 ^{cm}	MR
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	N/C	N/C	N/C
	• Fire check door	MR	NP	NMR
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	R	2 to 4m	MR
		R.	100 Mtr	

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.R	N.P	N.M.P
		/	/	/
		/	/	/
		/	/	/
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N.R	N.P	N.M.R
		30 a/c per hour	/	/
		12 a/c per hour	/	/
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R	Provided	M.R
		ISI marked	A.B.C type	/
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	N.R	N.P	N.M.R
		30 m	/	/
		5 mm	/	/
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.R	N.P	N.M.R
		/	/	/
		/	/	/
		/	/	/
8	MOEFA			
9	Public Address System.			
		N.R	N.P	N.M.R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.R	N.P	N.M.R
		N.C	N.C	N.C

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	/	/	/
12	Yard Hydrants.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	/	/	/
13	Pumping Arrangements.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	/	/	/
14	Captive Water Storage for fire fighting.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	/	/	/

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	/	/	/
15	Exit Signage.	N.R.	N.P.	N.M.R.
16	Provision of Lifts.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	/	/	/
17	Standby power supply	N.R.	N.P.	N.M.R.
18	Refuge Area.	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	/	/	/
19	Fire Control Room	N.R.	N.P.	N.M.R.
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	/	/	/
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.P.	N.M.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....MIC.....



Signature of the Inspecting Officer

Name H. L. Anys

Designation Div. Officer.

Signature of the Inspecting Officer

Name

Designation

