

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG(DAS)/MS/2011/2624

Dated: 20/10/2011

FIRE SAFETY CERTIFICATE

Certified that the Govt Sarvodaya Co-ed Vidhyalaya is comprised of Ground floor building thus below 09 mtrs, located at A-2, Paschim Vihar, New Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 13/09/2011 in the presence of Principal Smt Arun Bala and that the building premises is fit for occupancy of Group B Educational Building with effect from 20/10/11 for a period of three years subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities non-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

Issued on 20/10/11 at New Delhi by



Chief Fire Officer
For Director
Delhi Fire Service

Copy to

1. The Principal, Sarvodaya Co-ed Vidhyalaya, A-2 Paschim Vihar, New Delhi 110063
2. The Director of Education, Old Secretariat, Delhi

902

INSPECTION REPORT

1. Name & address of the building: Govt Sewadaya Co-Edu Vidyalaya
A-2, Paschim Vihar, N. Delhi-63
2. Type of Occupancy: school (Ground floor only)
3. Type of Case: New Case ~~Renewal~~
4. Details of previous NOC: Letter No. nil Dated: nil
5. Fire Safety directives letter No: nil (As per Dir of Edu. letter)
dttd 1-3-2011
6. Date of Inspection: 13/9/11
7. Name of the Inspecting Officers: SS Tuli ADO
8. Name and designation of officers from the building side: Smt Arun Bala, Principal
9. Year of Construction: -
10. Applicant's letter No: A2/PV/2011/6211 dttd 19/05/2011

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/SMR
1	Access to building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits	N/A	N/A	N/A
	i. Number of staircases	—	—	.
	• Upper Floors	—	—	—
	• Basements	—	—	—

b. Width of staircases	-	-	-
• Upper Floors	-	-	-
• Basements	-	-	-
c. Protection of exits	-	-	-
• Fire check door	-	-	-
• Pressurization	-	-	-
e. No. of continuous staircases to terrace	-	-	-
g. Width of Corridor	-	-	-
h. Door Size	-	-	-
Compartmentation.	NA	NA	NA
• Fire check door	-	-	-
• Sealing of electrical shafts	-	-	-
• Fire Rating of shaft door	-	-	-
• Water Curtain	-	-	-
• Fire Dampers	-	-	-

4	Smoke Management System.		N/A	N/A	N/A
	• Basements	30 a/c per hour	—	—	—
	• Upper floors	12 a/c per hour	—	—	—
5	Fire Extinguishers		Regd	Insided	MR
	• Total numbers			07 Nos	MR
	• Types	ISI marked		ABC	MR
	• IS marking			yes	MR
6	First-Aid Hose Reels.		NR	NR	NR
	• Total numbers on each floor			—	—
	• Length of hose reel hose	30 m		—	—
	• Nozzle diameter	5 mm		—	—
7	Automatic fire detection and alarming system.		NR	NR	NR
	• Type of detectors		—	—	—
	• Location of Main Panel		—	—	—
	• Location of Repeater Panel		—	—	—
	• Alternate source of power		—	—	—
	• Hooters' Location		—	—	—
8	MOEFA		NR	NR	NR
9	Public Address System.		NR	NR	NR

10	Automatic Sprinkler System.	NR	NP	NA
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants	NR	NP	NA
	• Size of riser down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—
12	Yard Hydrants.	NR	NP	NA
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements:	NR	NP	NA
	• Ground Level	—	—	—
	• Discharge of main Pump	—	—	—
	• Head of Main pump	—	—	—
	• Number of main pumps	—	—	—
	• Standby Pump out put	—	—	—
	• Jockey pump head	—	—	—
	• Standby Pump out put	—	—	—
	• Standby Pump Head	—	—	—

	➤ Auto Starting Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	Terrace level	-	-	-
	➤ Discharge of pump	-	-	-
	➤ Head of the pump	-	-	-
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	-	-	-
14	Captive Water Storage for fire fighting.	NR	NP	NA
	• Underground tank capacity.	-	-	-
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-

15	Exit Signage.	NR	NP	NA
16	Provision of Lifts:	NR	NP	NA
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	NR	NP	NA
18	Refuge Area.	NR	NP	NA
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NR	NP	NA
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• P A System Panel	—	—	—
	• Battery backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks/ if any	NR	NP	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name SS Tuli

Designation ADE(MN)

Signature of the Inspecting Officer

Name Sunil chawdhary

Designation D.O(MN)