

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI

No. FG/DFS/MS/school/2011/2730

Dated 28/10/2011

FIRE SAFETY CERTIFICATE

Certified that the Navyug Primary School, Pataudi House, New Delhi-110001 comprised of ground plus one upper floor below 09 meters in height located at Pataudi House, New Delhi-110001 have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16./Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011 issued by The Director of Education and verified by the officer concerned of this department on 17-10-2011 in presence of Mr. Jasbir Singh, FO CUM NA and the building is fit for occupancy class **Educational** with effect from ...28/10/2011... for a period of three years subject to conditions mentioned below.

Issued on 28/10/2011 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1

Shri Jasbir Singh, The Fire Officer Cum Nominated Authority, NDMC, Plika Kendra, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building: NAVYUGA PRIMARY SCHOOL Pataudi, N-Delhi class 1st to 5th
2. Type of Occupancy: Educational
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. - N.A. - Dated: N.A.
5. Fire Safety directives letter No: - N.A. -
6. Date of inspection: 17-10-2011
7. Name of the Inspecting Officers: D.S. Yadav
8. Name and designation of officers from the building side: Sri Jasbir Singh N.A cum nominated authority
9. Year of Construction: 1993-1994
10. Applicant's letter No: D/2269-FO cum N.A. dated 05-07-2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building	Requirement <i>Circular issued by Directorate of Education, dated 1-3-2011</i>		
	• Road width		More than 6 Mts	M.R
	• Gate width			M.R
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R
	• Basements	N.A	N.A	N.A
	b. Width of staircases			
	• Upper Floors		Upper stair 1.27m	M.R
	• Basements	N.A	R.C.C. Stair 1.25 to 1.3m	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	N.A	N.A	N.A
	h. Door Size	01-00	1.25	M.R

contd: -

NAVYUGA Primary School, Patendi House,
New Delhi - 110001

3	Compartmentation.	N.A	N.A	N.A
	• Fire check door	N.A	N.A	N.A
	• Sealing of electrical shafts	N.A	N.A	N.A
	• Fire Rating of shaft door	N.A	N.A	N.A
	• Water Curtain	N.A	N.A	N.A
	• Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N.A	N.A
	• Upper floors	12 a/c per hour	YES	M.R
5	Fire Extinguishers			
	• Total numbers		Total 12 Nos	M.R
	• Types		6 W. CO ₂ Type	M.R
	• IS marking	ISI marked	6 ABC Type 1 S-1 marked	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Not required	Provided 2 Nos.	M.R
	• Length of hose reel hose	30 m	30 M	M.R
	• Nozzle diameter	5 mm	5 M.M	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N.A	N.A	N.A
	• Location of Main Panel	N.A	N.A	N.A
	• Location of Repeater Panel	N.A	N.A	N.A
	• Alternate source of power	N.A	N.A	N.A
	• Hooters' Location	N.A	N.A	N.A
8	MOEFA	N.A	N.A	N.A
9	Public Address System.	Not required	Provided.	M.R
10	Automatic Sprinkler System.			
	• Basement	N.A	N.A	N.A

contd:-

NAVYUG PRIMARY SCHOOL
PATAUDI HOUSE
NEW DELHI - 110001

	➤ Fire service inlet	N.R	N.R	M.R
	➤ Access to tank	N.R	Provided	M.R.
	• Overhead Tank capacity	N.R	2500 litres	M.R.
15	Exit Signage.		Provided	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.R	N.R	N.R
	• Pressurization of Lift lobby	N.R	N.R	N.R
	• Communication In lift Car	N.R	N.R	N.R
	• Fireman's Grounding Switch	N.R	N.R	N.R
	• Lift Signage	N.R	N.R	N.R.
17	Standby power supply	N.R.	N.R.	N.R
18	Refuge Area.			
	➤ Total Area	N.R	N.R	N.R
	➤ Location	N.R.	N.R.	N.R.
19	Fire Control Room			
	• Detector System Panel	N.R	N.R	N.R
	• Flow Switch Panel	N.R	N.R	N.R
	• PA System Panel	N.R	N.R	N.R
	• Batter backup	N.R	N.R	N.R
	• Building Floor Plans	N.R	N.R	N.R
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

contd:-

NAVYUG PRIMARY SCHOOL
PATAUDI HOUSE
NEW DELHI-110001

(5)

Signature of the Inspecting Officer

[Signature]
Signature of the Inspecting Officer

Name

Name *D.S. Yadav*

Designation

Designation *Assistant divisional
officer*

[Faint handwritten marks]